Section 3.10. Objectives and Functional Statements

3.10.1. Objectives and Functional Statements

3.10.1.1. Attributions to Acceptable Solutions

1) For the purpose of compliance with this Code as required in Clause 1.2.1.1.(1)(b) of Division A, the objectives and functional statements attributed to the acceptable solutions in this Part shall be the objectives and functional statements listed in Table 3.10.1.1. (See Note A-1.1.2.1.(1).)

	Functional Statements and Objectives ⁽¹⁾	
3.1.3	3.1. Separation of Major Occupancies	
(1)	[F03-OS1.2]	
	[F03-OP1.2]	
(2)	[F03-OS1.2]	
(3)	[F02,F03,F06-OS1.2] [F10,F05-OS1.5]	
	[F02,F03,F06-OP1.2]	
3.1.3	3.2. Prohibition of Occupancy Combinations	
(1)	[F02,F03-OS1.2] [F10-OS1.5]	
(2)	[F02,F03-OS1.2]	
3.1.4	1.1. Combustible Materials Permitted	
(2)	[F02-OS1.2]	
	[F02-OP1.2]	
3.1.4	1.2. Protection of Foamed Plastics	
(1)	[F01-OS1.1] [F02-OS1.2]	
	[F01-OP1.1] [F02-OP1.2]	
(2)	[F01-OS1.1] [F02-OS1.2]	
	[F01-OP1.1] [F02-OP1.2]	
3.1.4	I.3. Wires and Cables	
(1)	[F02-OS1.2]	
	[F02-OP1.2]	
(2)	[F02-OS1.2]	
	[F02-OP1.2]	
(3)	[F02-OS1.2]	
	[F02-OP1.2]	
3.1.4	I.5. Fire-Retardant-Treated Wood	
(1)	[F02-OS1.2]	
	[F02-OP1.2]	
3.1.4	I.8. Exterior Cladding	
(1)	[F03,F02-OP3.1]	
	1	

	Functional Statements and Objectives ⁽¹⁾
0.4 -	
	.1. Noncombustible Materials
(1)	[F02-OS1.2]
	[F02-OP1.2]
	.5. Combustible Cladding on Exterior Walls
(2)	[F03,F02-OP3.1]
3.1.5	.21. Wires and Cables
(2)	[F02-OS1.2]
	[F02-OP1.2]
(3)	[F02-OS1.2]
	[F02-OP1.2]
3.1.5	.23. Non-metallic Raceways
(1)	[F02-OS1.2]
	[F02-OP1.2]
(2)	[F02-OS1.2]
	[F02-OP1.2]
3.1.6	.2. Restrictions
(1)	[F10,F12,F36-OS3.7]
	[F20-OS2.2]
(2)	[F10,F36-OS3.7] Applies to portion of Code text: "An air-supported structure shall not be used for Groups B, C, major occupancies or for classrooms."
	[F01,F02,F36-OS1.5] Applies to portion of Code text: "An air-supported structure shall not be used for Group F, Division 1 major occupancies"
(3)	[F10-OS3.7]
3.1.6	.3. Clearance to Other Structures
(2)	(a) [F03-OS1.2]
	(b) [F10-OS3.7]
	(a) [F03-OP3.1]
3.1.6	.4. Clearance to Flammable Material
(1)	[F01-OS1.1] [F03-OS1.2]
	[F01-OP1.1] [F03-OP1.2]
3.1.6	.5. Flame Resistance
(1)	[F02-OS1.2]
3.1.6	.6. Emergency Air Supply
(1)	[F20-OS3.7]
3.1.6	.7. Electrical Systems
(1)	[F34-OP1.1]
	[F34-OS3.3]
	[F34-OS1.1]

	Functional Statements and Objectives ⁽¹⁾	
(2)	-	
(2)	[F81-OP1.1]	
	[F81-OS1.1]	
	.1. Determination of Ratings	
(1)	[F03-OS1.2] [F04-OS1.3]	
	[F03-OP1.2] [F04-OP1.3]	
3.1.7	.5. Rating of Supporting Construction	
(1)	[F04-OS1.3]	
	[F04-OP1.3]	
(3)	[F04-OS1.3]	
	[F04-OP1.3]	
3.1.8	.1. General Requirements	
(1)	(a) [F03-OS1.2]	
	(a) [F03-OP1.2]	
(2)	[F03-OS1.2] Applies to the requirement that openings in <i>fire separations</i> be protected with <i>closures</i> , shafts or other means.	
	[F03-OP1.2] Applies to the requirement that openings in <i>fire separations</i> be protected with <i>closures</i> , shafts or other means.	
3.1.8	.2. Combustible Construction Support	
(1)	[F04-OS1.2]	
	[F04-OP1.2]	
3.1.8	.3. Continuity of Fire Separations	
(1)	[F03-OS1.2]	
	[F03-OP1.2]	
(2)	[F03-OS1.2]	
	[F03-OP1.2]	
(3)	(a) [F03-OS1.2]	
	(a) [F03-OP1.2]	
	(b) [F03-OS1.2]	
	(b) [F03-OP1.2]	
(4)	[F03-OS1.2]	
	[F03-OP1.2]	
3.1.8	.4. Determination of Ratings and Classifications	
(1)	[F03-OS1.2]	
	[F03-OP1.2]	
(2)	[F03-OS1.2]	
	[F03-OP1.2]	
(3)	[F03-OS1.2]	
	[F03-OP1.2]	
L		

	Functional Statements and Objectives ⁽¹⁾	
(4)	[F03-OS1.2]	
()	[F03-OP1.2]	
3.1.8	.5. Installation of Closures	
(2)	[F03-OS1.2]	
	[F03-OP1.2]	
(3)	[F03-OS1.2]	
	[F03-OP1.2]	
(4)	[F81-OS1.2]	
	[F81-OP1.2]	
(5)	[F81-OP1.2]	
	[F81-OS1.2]	
(6)	[F03-OS1.2]	
	[F03-OP1.2]	
(7)	[F03-OS1.2]	
	[F03-OP1.2]	
3.1.8	.6. Maximum Openings	
(1)	[F03-OS1.2]	
	[F03-OP1.2]	
(2)	[F03-OS1.2]	
	[F03-OP1.2]	
3.1.8	.7. Location of Fire Dampers and Smoke Dampers	
(1)	[F03-OS1.2]	
	[F03-OP1.2]	
(2)	[F03-OS1.2]	
	[F03-OP1.2]	
3.1.8	.10. Installation of Fire Dampers	
(1)	[F04-OS1.2]	
	[F04-OP1.2]	
(2)	[F03-OS1.2]	
	[F03-OP1.2]	
(3)	[F03-OS1.2]	
	[F03-OP1.2]	
(4)	[F03-OS1.2]	
	[F03-OP1.2]	

Objectives and Functional Statements Attributed to the Acceptable Solutions in Part 3

Functional Statements and Objectives ⁽¹⁾
[F82-OS1.2] Applies to portion of Code text: "A tightly fitted access door shall be installed for each <i>fire damper</i> to provide access for the inspection of the damper"
[F82-OP1.2] Applies to portion of Code text: "A tightly fitted access door shall be installed for each <i>fire damper</i> to provide access for the inspection of the damper"
[F82-OH1.2] Applies to portion of Code text: "A tightly fitted access door shall be installed for each <i>fire damper</i> to provide access for the resetting of the release device."
.11. Installation of Smoke Dampers
[F03-OS1.2]
[F03-OP1.2]
[F82-OS1.2] Applies to portion of Code text: "A tightly fitted access door shall be installed for each smoke damper to provide access for the inspection of the damper"
[F82-OH1.2] Applies to portion of Code text: "A tightly fitted access door shall be installed for each smoke damper to provide access for the inspection of the damper"
[F82-OP1.2] Applies to portion of Code text: "A tightly fitted access door shall be installed for each <i>fire damper</i> to provide access for the resetting of the release device."
.12. Twenty-Minute Closures
[F03-OS1.2]
[F03-OP1.2]
.13. Self-closing Devices
[F03-OS1.2]
[F03-OP1.2]
1.14. Hold-Open Devices
[F03-OS1.2]
[F03-OS1.2]
[F03-OP1.2]
[F03-OS1.2]

	Functional Statements and Objectives ⁽¹⁾
3.1.8	1.15. Door Latches
(1)	[F03-OS1.2]
	[F03-OP1.2]
3.1.8	16. Wired Glass and Glass Block
(3)	[F04-OS1.2] Applies to portion of Code text: "Glass blocks permitted by Sentence (1) shall be reinforced with steel reinforcement in each horizontal joint."
	[F04-OP1.2] Applies to portion of Code text: "Glass blocks permitted by Sentence (1) shall be reinforced with steel reinforcement in each horizontal joint."
3.1.8	.17. Temperature Rise Limit for Doors
(1)	[F03,F31-OS1.2] [F05-OS1.5]
	[F03-OP1.2]
3.1.8	2.18. Area Limits for Wired Glass and Glass Block
(1)	[F05-OS1.5] [F31-OS1.2]
	[F30-OS3.1]
(2)	[F05-OS1.5] [F31-OS1.2]
3.1.9	.1. Fire Stops
(1)	[F03-OS1.2] [F04-OS1.3]
	[F03-OP1.2] [F04-OP1.3]
(2)	[F03-OS1.2]
	[F03-OP3.1]
	[F03-OP1.2]
(3)	[F03-OS1.2]
	[F03-OP1.2]
3.1.9	2.2. Combustibility of Service Penetrations
(1)	[F03-OS1.2] [F02,F04-OS1.3] Applies to portion of Code text: "Except as permitted by Articles 3.1.9.3. and 3.1.9.5., pipes, ducts, electrical outlet boxes, totally enclosed raceways or other similar service equipment that penetrate an assembly required to have a <i>fire-resistance rating</i> shall be <i>noncombustible</i> "
	[F03-OP1.2] [F02,F04-OP1.3] Applies to portion of Code text: "Except as permitted by Articles 3.1.9.3. and 3.1.9.5., pipes, ducts, electrical outlet boxes, totally enclosed raceways or other similar service equipment that penetrate an assembly required to have a <i>fire-resistance rating</i> shall be <i>noncombustible</i> "
3.1.9	.4. Penetration by Outlet Boxes
(1)	[F03-OS1.2]
	[F03-OP1.2]
(3)	[F03-OS1.2]
	[F03-OP1.2]
3.1.9	.5. Combustible Piping Penetrations
(3)	[F03-OS1.2] [F02,F04-OS1.3]
	[F03-OP1.2] [F02,F04-OP1.3]

	Functional Statements and Objectives ⁽¹⁾
3.1.9	9.6. Openings through a Membrane Ceiling
(1)	[F04-OS1.3]
	[F04-OP1.3]
3.1.1	0.1. Prevention of Firewall Collapse
(1)	[F04-OP1.2]
	[F04-OS1.2]
	[F04-OP3.1]
(2)	[F03,F04-OP1.2]
	[F03,F04-OS1.2]
	[F03,F04-OP3.1]
(4)	[F04-OS1.2]
	[F04-OP1.2]
	[F04-OP3.1]
3.1.1	0.2. Rating of Firewalls
(1)	[F03-OS1.2] Applies to portion of Code text: "A <i>firewall</i> that separates a <i>building</i> or <i>buildings</i> with <i>floor areas</i> containing a Group E or a Group F, Division 1 or 2 <i>major occupancy</i> shall be constructed as a <i>fire separation</i> of <i>noncombustible construction</i> having a <i>fire-resistance rating</i> not less than 4 h"
	[F03-OP1.2] Applies to portion of Code text: "A <i>firewall</i> that separates a <i>building</i> or <i>buildings</i> with <i>floor areas</i> containing a Group E or a Group F, Division 1 or 2 <i>major occupancy</i> shall be constructed as a <i>fire separation</i> of <i>noncombustible construction</i> having a <i>fire-resistance rating</i> not less than 4 h"
	[F03-OP3.1] Applies to portion of Code text: "A <i>firewall</i> that separates a <i>building</i> or <i>buildings</i> with <i>floor areas</i> containing a Group E or a Group F, Division 1 or 2 <i>major occupancy</i> shall be constructed as a <i>fire separation</i> of <i>noncombustible construction</i> having a <i>fire-resistance rating</i> not less than 4 h"
(2)	[F03-OS1.2]
	[F03-OP1.2]
	[F03-OP3.1]
(3)	[F80,F04-OP1.2]
	[F80,F04-OS1.2]
	[F80,F04-OP1.3]
(4)	[F80,F04-OP1.2]
	[F80,F04-OS1.2]
	[F80,F04-OP3.1]
3.1.1	10.3. Continuity of Firewalls
(1)	[F03-OS1.2] Applies to portion of Code text: "A <i>firewall</i> shall extend from the ground continuously through, or adjacent to, all <i>storeys</i> of a <i>building</i> or <i>buildings</i> so separated"
	[F03-OP1.2] Applies to portion of Code text: "A <i>firewall</i> shall extend from the ground continuously through, or adjacent to, all <i>storeys</i> of a <i>building</i> or <i>buildings</i> so separated"
	[F03-OP3.1] Applies to portion of Code text: "A <i>firewall</i> shall extend from the ground continuously through, or adjacent to, all <i>storeys</i> of a <i>building</i> or <i>buildings</i> so separated"

Functional Statements and Objectives ⁽¹⁾
0.4. Parapets
[F03-OP1.2]
[F03-OS1.2]
[F03-OP3.1]
0.5. Maximum Openings
[F03-OP1.2] Applies to portion of Code text: " the aggregate width of openings shall be not more than 25% of the entire length of the firewall."
[F03-OS1.2] Applies to portion of Code text: " the aggregate width of openings shall be not more than 25% of the entire length of the firewall."
[F03-OP3.1] Applies to portion of Code text: " the aggregate width of openings shall be not more than 25% of the entire length of the firewall."
0.7. Combustible Projections
[F03-OP1.2] Applies to portion of Code text: "Combustible material shall not extend across the end of a firewall"
[F03-OS1.2] Applies to portion of Code text: "Combustible material shall not extend across the end of a firewall"
[F03-OP3.1] Applies to portion of Code text: "Combustible material shall not extend across the end of a firewall"
[F03-OS1.2]
[F03-OP1.2]
[F03-OP3.1]
1.1. Separation of Concealed Spaces
[F03-OS1.2]
[F03-OP1.2]
1.2. Fire Blocks in Wall Assemblies
[F03-OS1.2]
[F03-OP1.2]
1.3. Fire Blocks between Nailing and Supporting Elements
[F03-OS1.2]
[F03-OP1.2]
1.4. Fire Blocks between Vertical and Horizontal Spaces
[F03-OS1.2]
[F03-OP1.2]

	Functional Statements and Objectives ⁽¹⁾
311	1.5. Fire Blocks in Horizontal Concealed Spaces
(1)	[F03,F04-OS1.2]
(')	[F03,F04-OP1.2]
(2)	[F03,F04-OS1.2]
(2)	[F03,F04-OP1.2]
(3)	[F02,F03-OP1.2] [F04-OP1.3]
(3)	[F02,F03-OF1.2][F04-OF1.3]
(4)	[F02, F03-OS1.2]
	[]
	2[F02, F03-OP1.2]
× i	
3.1.1	1.6. Fire Blocks in Crawl Spaces
(1)	[F03,F04-OS1.2]
	[F03,F04-OP1.2]
3.1.1	1.7. Fire Block Materials
(1)	[F04-OS1.2]
	[F04-OP1.2]
(<u>6</u>)	[F04-OP1.2]
	[F04-OS1.2]
(<u>7</u>)	[F03-OP1.2]
	[F03-OS1.2]
3.1.1	2.1. Determination of Ratings
(1)	[F02-OS1.2]
	[F02-OP1.2]
(2)	[F02-OS1.2]
	[F02-OP1.2]
3.1.1	3.2. Flame-Spread Rating
(1)	[F02-OS1.2]
	[F02-OP1.2]
3.1.1	3.5. Skylights
(1)	[F02-OS1.5]
3.1.1	3.6. Corridors
(1)	[F02-OS1.2,OS1.5]
	[F02-OP1.2]
(5)	[F02-OS1.2,OS1.5]
	[F02-OP1.2]

	Functional Statements and Objectives ⁽¹⁾
(6)	[F02-OS1.2]
(0)	[F02-OP1.2]
3.1.1	3.7. High Buildings
(1)	[F02-OS1.2]
(')	[F02-OP1.2]
211	3.9. Underground Walkways
(1)	[F02-OS1.2]
(1)	[F02-OP3.1]
211	3.10. Exterior Exit Passageway
	[F02-OS1.5]
(1)	3.11. Elevator Cars
(1)	[F02-OS1.2]
(0)	[F02-OP1.2]
(2)	[F02-OS1.2]
	[F02-OP1.2]
	4.1. Fire-Retardant-Treated Wood Roof Systems
(1)	[F02-OS1.2]
	[F02-OP1.2]
(2)	[F02-OS1.3,OS1.2]
	[F02-OP1.3]
3.1.1	4.2. Metal Roof Deck Assemblies
(1)	[F02-OS1.2]
	[F02-OP1.2]
3.1.1	5.1. Roof Covering Classification
(1)	[F02-OS1.2]
	[F02-OP1.2]
	[F02-OP3.1]
3.1.1	5.2. Roof Coverings
(1)	[F02-OS1.2]
	[F02-OP1.2]
	[F02-OP3.1]
(3)	[F02-OS1.2]
	[F02-OP1.2]
	[F02-OP3.1]
<u>(4)</u>	[F02-OS1.2]
	[F02-OP1.2]
	[F02-OP3.1]
60008	N

	Functional Statements and Objectives ⁽¹⁾
3.1.1	6.1. Fabric Canopies and Marquees
(1)	[F02-OS1.2,OS1.5]
	[F02-OP1.2]
3.1.1	7.1. Occupant Load Determination
(1)	[F10-OS3.7]
	[F72-OH2.1] [F71-OH2.3]
(2)	[F10-OS3.7]
	[F72-OH2.1] [F71-OH2.3]
(4)	[F10-OS3.7]
	[F72-OH2.1] [F71-OH2.3]
3.1.1	8.2. Materials Permitted
) U	[F02-OS1.2]
***	<u>[F02-OP1.2]</u>
3.1.1	8.3. Structural Mass Timber Elements
(2)	[F04-OS1.3]
	[F04-OP1.3]
<u>(3)</u>	<u>[F02-OS1.2]</u>
	<u>[F02-OP1.2]</u>
3.1.1	8.4. Encapsulation of Mass Timber Elements
<u> </u>	<u>1F02-OS1.21</u>
	<u>[F02-OP1.2]</u>
(2)	<u>[F02-0S1.2]</u>
ğ}	<u>[F02-OP1.2]</u>
3.1.1	8.7. Exterior Cladding
<u>(1)</u>	<u>[F02-0S1.2]</u>
8	<u>[F02-OP1.2]</u>
<u>(5)</u>	<u>[F02, F03-OP3.1]</u>
	<u>[F03-OS1.2]</u>
ğ)	<u>[F03-OP1.2]</u>
<u>3.1.1</u>	8.15. Penetration by Outlet Boxes
<u>(3)</u>	[F03-OS1.2]
	<u>[F03-OP1.2]</u>
3.1.1	9.1. Determination of Ratings
<u>m</u>	[<u>[F02-OS1.2]</u>
X S	2[F04-OS1.3]
Š	[<u>F02-OP1.2]</u>
ğ	<u>[F04-OP1.3]</u>
. X X X X	***************************************

	Functional Statements and Objectives ⁽¹⁾	
3.2.1	.2. Storage Garage Considered as a Separate Building	
(1)	[F03-OS1.2]	
	[F03-OP1.2]	
(2)	[F03-OS1.2]	
	[F03-OP1.2]	
(3)	[F03-OS1.2]	
	[F03-OP1.2]	
3.2.1	.4. Floor Assembly over Basement	
(1)	[F03-OS1.2] [F04-OS1.3]	
	[F03-OP1.2] [F04-OP1.3]	
(2)	[F04-OS1.2,OS1.3]	
	[F04-OP1.2,OP1.3]	
3.2.1	.5. Fire Containment in Basements	
(1)	[F02-OS1.2,OS1.3]	
	[F02-OP1.2,OP1.3]	
3.2.2.2. Special and Unusual Structures		
(1)	[F02,F03,F04-OS1.2,OS1.3]	
	[F02,F03,F04-OP1.2,OP1.3]	
3.2.2	.6. Multiple Major Occupancies	
(1)	[F02,F03,F04-OS1.2,OS1.3]	
	[F02,F03,F04-OP1.2,OP1.3]	
3.2.2	.10. Streets	
(1)	[F12-OS1.2,OS1.5]	
	[F12-OP1.2]	
3.2.2	.15. Storeys below Ground	
(2)	(a) [F02,F04-OS1.2,OS1.3]	
	(a) [F02,F04-OP1.2,OP1.3]	
	(b),(c) [F03-OS1.2] [F04-OS1.2,OS1.3]	
	(b),(c) [F03-OP1.2] [F04-OP1.2,OP1.3]	
3.2.2	.18. Automatic Sprinkler System Required	
(2)	[F02,F04-OS1.2,OS1.3]	
	[F02,F04-OP1.2,OP1.3]	

Objectives and Functional Statements Attributed to the Acceptable Solutions in Part 3

	Eurotional Statements and Objectives(1)
2.0.4	Functional Statements and Objectives ⁽¹⁾
	2.20. Group A, Division 1, Any Height, Any Area, Sprinklered
(2)	[F02-OS1.2] Applies to portion of Code text: " the <i>building</i> referred to in Sentence (1) shall be of <i>noncombustible construction</i> "
	[F02-OP1.2] Applies to portion of Code text: " the <i>building</i> referred to in Sentence (1) shall be of <i>noncombustible construction</i> "
	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the <i>building</i> shall be <i>sprinklered</i> throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the <i>building</i> shall be <i>sprinklered</i> throughout"
	(b),(d) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(b),(d) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(c),(d) [F04-OS1.3]
	(c),(d) [F04-OP1.3]
3.2.2	2.21. Group A, Division 1, One Storey, Limited Area, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the <i>building</i> is <i>sprinklered</i> throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the <i>building</i> is <i>sprinklered</i> throughout"
(2)	[F02-OS1.2] Applies to portion of Code text: "The <i>building</i> referred to in Sentence (1) is permitted to be of <i>heavy timber construction</i> or <i>noncombustible construction</i> used singly or in combination"
	[F02-OP1.2] Applies to portion of Code text: "The <i>building</i> referred to in Sentence (1) is permitted to be of <i>heavy timber construction</i> or <i>noncombustible construction</i> used singly or in combination"
	[F03-OS1.2] [F04-OS1.2,OS1.3] Applies to portion of Code text: " (a) floor assemblies shall be <i>fire separations</i> (i) with a <i>fire-resistance rating</i> not less than 45 min" and to Clause (b).
	[F03-OP1.2] [F04-OP1.2,OP1.3] Applies to portion of Code text: " (a) floor assemblies shall be <i>fire separations</i> (i) with a <i>fire-resistance rating</i> not less than 45 min" and to Clause (b).
3.2.7	2.22. Group A, Division 1, One Storey, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
(2)	[F03-OS1.2] [F04-OS1.2,OS1.3] Applies to portion of Code text: " a) floor assemblies shall be <i>fire separations</i> with a <i>fire-resistance rating</i> not less than 45 min," and to Clause (d).
	[F03-OP1.2] [F04-OP1.2,OP1.3] Applies to portion of Code text: " a) floor assemblies shall be <i>fire separations</i> with a <i>fire-resistance rating</i> not less than 45 min," and to Clause (d).
	(b),(c) [F04-OS1.3]
	(b),(c) [F04-OP1.3]
3.2.2	2.23. Group A, Division 2, Any Height, Any Area, Sprinklered
	2.23. Group A, Division 2, Any Height, Any Area, Sprinklered [F02-OS1.2] Applies to portion of Code text: " the <i>building</i> referred to in Sentence (1) shall be of <i>noncombustible construction</i> "
	[F02-OS1.2] Applies to portion of Code text: " the <i>building</i> referred to in Sentence (1) shall be of <i>noncombustible construction</i> "
	[F02-OS1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction" [F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	[F02-OS1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction" [F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction" [F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction" [F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building shall be sprinklered throughout"
	[F02-OS1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction" [F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction" [F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction" [F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building shall be sprinklered throughout" [F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building shall be sprinklered throughout"
3.2.2 (2)	[F02-OS1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction" [F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction" [F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction" [F02-OP1.2] Applies to portion of Code text: " a) the building shall be sprinklered throughout" [F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building shall be sprinklered throughout" [F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building shall be sprinklered throughout" (b),(d) [F03-OS1.2] [F04-OS1.2,OS1.3]

	Functional Statements and Objectives ⁽¹⁾
3.2.2	.24. Group A, Division 2, up to 6 Storeys, Any Area, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the <i>building</i> is <i>sprinklered</i> throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the <i>building</i> is <i>sprinklered</i> throughout"
(2)	[F02-OS1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	[F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	(a),(c) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(c) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(c) [F04-OS1.3]
	(b),(c) [F04-OP1.3]
3.2.2	.25. Group A, Division 2, up to 2 Storeys
(2)	[F04-OS1.3] Applies to portion of Code text: " c) roof assemblies shall have, if of <i>combustible construction</i> , a <i>fire-resistance rating</i> not less than 45 min," and to <i>Clause (d)</i> .
	[F04-OP1.3] Applies to portion of Code text: " c) roof assemblies shall have, if of <i>combustible construction</i> , a <i>fire-resistance rating</i> not less than 45 min," and to <i>Clause (d)</i> .
	(a) [F03-OS1.2] Applies to the requirement that noncombustible floor assemblies be fire separations.
	(a) [F03-OP1.2] Applies to the requirement that noncombustible floor assemblies be fire separations.
	(a),(d) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(d) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(d) [F04-OS1.3]
	(b),(d) [F04-OP1.3]
3.2.2	.26. Group A, Division 2, up to 2 Storeys, Increased Area, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
(2)	(a) [F03-OS1.2] Applies to the requirement that noncombustible floor assemblies be fire separations.
	(a) [F03-OP1.2] Applies to the requirement that noncombustible floor assemblies be fire separations.
	(a),(c) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(c) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(c) [F04-OS1.3]
	(b),(c) [F04-OP1.3]
3.2.2	.27. Group A, Division 2, up to 2 Storeys, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
3.2.2	.28. Group A, Division 2, One Storey
(2)	[F03-OP1.2]
、 /	[F03-OS1.2]

Table 3.10.1.1. (continued) Objectives and Functional Statements Attributed to the Acceptable Solutions in Part 3

	Functional Statements and Objectives ⁽¹⁾
3.2.2	2.29. Group A, Division 3, Any Height, Any Area, Sprinklered
(2)	[F02-OS1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	[F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building shall be sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building shall be sprinklered throughout"
	(b),(d) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(b),(d) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(c),(d) [F04-OS1.3]
	(c),(d) [F04-OP1.3]
3.2.2	2.30. Group A, Division 3, up to 2 Storeys
(2)	[F02-OS1.2] Applies to portion of Code text: "Except as permitted by Clauses (c) and (d), the <i>building</i> referred to in Sentence (1) shall be of <i>noncombustible construction</i> "
	[F02-OP1.2] Applies to portion of Code text: "Except as permitted by Clauses (c) and (d), the <i>building</i> referred to in Sentence (1) shall be of <i>noncombustible construction</i> "
	(a),(d) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(d) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(d) [F04-OS1.3]
	(b),(d) [F04-OP1.3]
	[F04-OS1.3] Applies to portion of Code text: " c) roof assemblies shall (i) have a fire-resistance rating not less than 45 min," and to Clause (d).
	[F04-OP1.3] Applies to portion of Code text: " c) roof assemblies shall (i) have a fire-resistance rating not less than 45 min," and to Clause (d).
(3)	[F02-OS1.2] [F04-OS1.3]
	[F02-OP1.2] [F04-OP1.3]
3.2.2	2.31. Group A, Division 3, up to 2 Storeys, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
(2)	[F02-OS1.2] Applies to portion of Code text: "Except as permitted by Clause (c) the <i>building</i> referred to in Sentence (1) shall be of <i>noncombustible</i> construction"
	[F02-OP1.2] Applies to portion of Code text: "Except as permitted by Clause (c) the <i>building</i> referred to in Sentence (1) shall be of <i>noncombustible</i> construction"
	(a),(c) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(c) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(c) [F04-OS1.3]
	(b),(c) [F04-OP1.3]

	Functional Statements and Objectives ⁽¹⁾
3.2.2	2.32. Group A, Division 3, One Storey, Increased Area
(2)	(a),(c) [F04-OS1.3]
	(a),(c) [F04-OP1.3]
	[F04-OS1.3] Applies to portion of Code text: " b) roof assemblies shall have, if of <i>combustible construction</i> , a <i>fire-resistance rating</i> not less than 45 min," and to Clause (c).
	[F04-OP1.3] Applies to portion of Code text: " b) roof assemblies shall have, if of <i>combustible construction</i> , a <i>fire-resistance rating</i> not less than 45 min," and to Clause (c).
(3)	[F02-OS1.2] [F04-OS1.3]
	[F02-OP1.2] [F04-OP1.3]
3.2.2	.33. Group A, Division 3, One Storey, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
3.2.2	.35. Group A, Division 4
(1)	[F02-OS1.2] Applies to portion of Code text: " a building classified as Group A, Division 4 shall be of noncombustible construction."
	[F02-OP1.2] Applies to portion of Code text: " a building classified as Group A, Division 4 shall be of noncombustible construction."
(4)	[F02,F04-OS1.2,OS1.3]
	[F02,F04-OP1.2,OP1.3]
3.2.2	 .36. Group B, Division 1, Any Height, Any Area, Sprinklered
(2)	[F02-OS1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	[F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building shall be sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building shall be sprinklered throughout"
	(b),(d) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(b),(d) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(c),(d) [F04-OS1.3]
	(c),(d) [F04-OP1.3]
3.2.2	
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
(2)	[F02-OS1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	[F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	(a),(c) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(c) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(c) [F04-OS1.3]
	(b),(c) [F04-OP1.3]

Table 3.10.1.1. (continued) Objectives and Functional Statements Attributed to the Acceptable Solutions in Part 3

	Functional Statements and Objectives ⁽¹⁾
3.2.2	2.38. Group B, Division 2, Any Height, Any Area, Sprinklered
(2)	[F02-OS1.2] Applies to portion of Code text: " the <i>building</i> referred to in Sentence (1) shall be of <i>noncombustible construction</i> "
	[F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building shall be sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building shall be sprinklered throughout"
	(b),(d) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(b),(d) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(c),(d) [F04-OS1.3]
	(c),(d) [F04-OP1.3]
3.2.2	2.39. Group B, Division 2, up to 3 Storeys, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
(2)	[F02-OS1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	[F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	(a),(c) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(c) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(c) [F04-OS1.3]
	(b),(c) [F04-OP1.3]
3.2.2	2.40. Group B, Division 2, up to 2 Storeys, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
(2)	(a),(c) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(c) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(c) [F04-OS1.3]
	(b),(c) [F04-OP1.3]
3.2.2	2.41. Group B, Division 2, One Storey, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
3.2.2	2.42. Group B, Division 3, Any Height, Any Area, Sprinklered
(2)	[F02-OS1.2] Applies to portion of Code text: " the <i>building</i> referred to in Sentence (1) shall be of <i>noncombustible construction</i> "
	[F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the <i>building</i> shall be <i>sprinklered</i> throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the <i>building</i> shall be <i>sprinklered</i> throughout"
	(b),(d) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(b),(d) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(c),(d) [F04-OS1.3]

	Functional Statements and Objectives ⁽¹⁾
	.43. Group B, Division 3, up to 3 Storeys (Noncombustible), Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the <i>building</i> is <i>sprinklered</i> throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the <i>building</i> is <i>sprinklered</i> throughout"
(2)	[F02-OS1.2] Applies to portion of Code text: " the <i>building</i> referred to in Sentence (1) shall be of <i>noncombustible construction</i> "
	[F02-OP1.2] Applies to portion of Code text: " the <i>building</i> referred to in Sentence (1) shall be of <i>noncombustible construction</i> "
	(a),(c) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(c) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(c) [F04-OS1.3]
	(b),(c) [F04-OP1.3]
3.2.2	.44. Group B, Division 3, up to 3 Storeys, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
(2)	[F03-OS1.2] [F04-OS1.2,OS1.3] Applies to portion of Code text: "a) floor assemblies shall be <i>fire separations</i> with a <i>fire-resistance rating</i> not less than 1 h," and to Clause (c).
	[F03-OP1.2] [F04-OP1.2,OP1.3] Applies to portion of Code text: "a) floor assemblies shall be <i>fire separations</i> with a <i>fire-resistance rating</i> not less than 1 h," and to Clause (c).
	(b),(c) [F04-OS1.3]
	(b),(c) [F04-OP1.3]
3.2.2	.45. Group B, Division 3, up to 2 Storeys, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
(2)	(a),(c) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(c) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(c) [F04-OS1.3]
	(b),(c) [F04-OP1.3]
3.2.2	.46. Group B, Division 3, One Storey, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
3.2.2	.47. Group C, Any Height, Any Area, Sprinklered
(2)	[F02-OS1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	[F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building shall be sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building shall be sprinklered throughout"
	(b),(d) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(b),(d) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(c),(d) [F04-OS1.3]
	(c),(d) [F04-OP1.3]

Objectives and Functional Statements Attributed to the Acceptable Solutions in Part 3

	Functional Statements and Objectives ⁽¹⁾
	.48. Group C, up to 6 Storeys, Sprinklered, Noncombustible Construction
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the <i>building</i> is <i>sprinklered</i> throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the <i>building</i> is <i>sprinklered</i> throughout"
(2)	[F02-OS1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	[F02-OP1.2] Applies to portion of Code text: " the <i>building</i> referred to in Sentence (1) shall be of <i>noncombustible construction</i> "
	(a),(c) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(c) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(c) [F04-OS1.3]
	(b),(c) [F04-OP1.3]
3.2.2	.48EMTC. Group C, up to 12 storeys, Sprinklered
<u>(1)</u>	[F02;F04-OP1.2, OP1.3] Applies to portion of Code text: "the building is sprinklered throughout"
(2)	(<u>b), (c) [F04-OS1.3]</u>
	(<u>b), (c) [F04-OP1.3]</u>
	(<u>a), (c) [F03-OS1.2] [F04-OS1.2, OS1.3]</u>
	<u>(a), (c) [F03-OP1.2] [F04-OP1.2, OP1.3]</u>
3.2.2	.49. Group C, up to 3 Storeys, Noncombustible Construction
(2)	[F02-OS1.2] Applies to portion of Code text: "The building referred to in Sentence (1) shall be of noncombustible construction"
	[F02-OP1.2] Applies to portion of Code text: "The building referred to in Sentence (1) shall be of noncombustible construction"
	[F03-OS1.2] [F04-OS1.2,OS1.3] Applies to portion of Code text: "a) floor assemblies shall be <i>fire separation</i> with a <i>fire-resistance rating</i> not less than 1 h," and to Clause (d).
	[F03-OP1.2] [F04-OP1.2, OP1.3] Applies to portion of Code text: " a) floor assemblies shall be <i>fire separations</i> with a <i>fire-resistance rating</i> not less than 1 h," and to Clause (d).
	(b),(d) [F04-OS1.3]
	(b),(d) [F04-OP1.3]
	(c),(d) [F04-OS1.3]
	(c),(d) [F04-OP1.3]
3.2.2	.50. Group C, up to 6 Storeys, Sprinklered
(1)	(a) [F02,F04-OS1.2,OS1.3]
	(a) [F02,F04-OP1.2,OP1.3]
(2)	[F03-OS1.2] [F04-OS1.2,OS1.3] Applies to portion of Code text: "a) floor assemblies shall be <i>fire separations</i> with a <i>fire-resistance rating</i> not less than 1 h," and to Clause (e).
	[F03-OP1.2] [F04-OP1.2,OP1.3] Applies to portion of Code text: " a) floor assemblies shall be <i>fire separations</i> with a <i>fire-resistance rating</i> not less than 1 h," and to Clause (e).
	(b),(d),(e) [F04-OS1.3]
	(b),(d),(e) [F04-OP1.3]
	[F02-OS1.2] Applies to portion of Code text: "c) the roof assembly shall be constructed of <i>noncombustible construction</i> or <i>fire-retardant-treated</i> wood conforming to Article 3.1.4.5.,
	[F02-OP1.2] Applies to portion of Code text: "c) the roof assembly shall be constructed of <i>noncombustible construction</i> or <i>fire-retardant-treated</i> wood conforming to Article 3.1.4.5.,

	Functional Statements and Objectives ⁽¹⁾	
3.2.2	51. Group C, up to 4 Storeys, Sprinklered	
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"	
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"	
(2)	[F03-OS1.2] [F04-OS1.2,OS1.3] Applies to portion of Code text: "a) floor assemblies shall be <i>fire separations</i> with a <i>fire-resistance rating</i> not less than 1 h," and to Clause (c).	
	[F03-OP1.2] [F04-OP1.2,OP1.3] Applies to portion of Code text: "a) floor assemblies shall be <i>fire separations</i> with a <i>fire-resistance rating</i> not less than 1 h," and to Clause (c).	
	(b),(c) [F04-OS1.3]	
	(b),(c) [F04-OP1.3]	
3.2.2	52. Group C, up to 3 Storeys, Increased Area	
(2)	[F03-OS1.2] [F04-OS1.2,OS1.3] Applies to portion of Code text: " a) floor assemblies shall be <i>fire separations</i> with a <i>fire-resistance rating</i> not less than 1 h," and to Clause (d).	
	[F03-OP1.2] [F04-OP1.2,OP1.3] Applies to portion of Code text: " a) floor assemblies shall be <i>fire separations</i> with a <i>fire-resistance rating</i> not less than 1 h," and to Clause (d).	
	(b),(d) [F04-OS1.3]	
	(b),(d) [F04-OP1.3]	
	(c),(d) [F04-OS1.3]	
	(c),(d) [F04-OP1.3]	
3.2.2	53. Group C, up to 3 Storeys	
(2)	[F03-OS1.2] [F04-OS1.2,OS1.3] Applies to portion of Code text: " a) floor assemblies shall be <i>fire separations</i> with a <i>fire-resistance rating</i> not less than 45 min," and to Clause c).	
	[F03-OP1.2] [F04-OP1.2,OP1.3] Applies to portion of Code text: "a) floor assemblies shall be fire separations with a fire-resistance rating not less than 45 min," and to Clause (d)	
	(b),(c) [F04-OS1.3]	
	(b),(c) [F04-OP1.3]	
3.2.2	54. Group C, up to 3 Storeys, Sprinklered	
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"	
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"	
(2)	[F03-OS1.2] [F04-OS1.2,OS1.3] Applies to portion of Code text: " a) floor assemblies shall be <i>fire separations</i> with a <i>fire-resistance rating</i> not less than 45 min," and to Clause (c).	
	[F03-OP1.2] [F04-OP1.2,OP1.3] Applies to portion of Code text: " a) floor assemblies shall be <i>fire separations</i> with a <i>fire-resistance rating</i> not less than 45 min," and to Clause (c).	
	(b),(c) [F04-OS1.3]	
	(b),(c) [F04-OP1.3]	

Objectives and Functional Statements Attributed to the Acceptable Solutions in Part 3 Forming Part of Sentence 3.10.1.1.(1)

Functional Statements and Objectives⁽¹⁾ 3.2.2.55. Group D, Any Height, Any Area, Sprinklered [F02-OS1.2] Applies to portion of Code text: "... the building referred to in Sentence (1) shall be of noncombustible construction ..." (2)[F02-OP1.2] Applies to portion of Code text: "... the building referred to in Sentence (1) shall be of noncombustible construction ..." [F02,F04-OS1.2,OS1.3] Applies to portion of Code text: "... a) ... the building shall be sprinklered throughout ..." [F02,F04-OP1.2,OP1.3] Applies to portion of Code text: "... a) ... the building shall be sprinklered throughout ..." (b),(d) [F03-OS1.2] [F04-OS1.2,OS1.3] (b),(d) [F03-OP1.2] [F04-OP1.2,OP1.3] (c),(d) [F04-OS1.3] (c),(d) [F04-OP1.3] 3.2.2.56. Group D, up to 6 Storeys (2) [F02-OS1.2] Applies to portion of Code text: "The building referred to in Sentence (1) shall be of noncombustible construction ..." [F02-OP1.2] Applies to portion of Code text: "The building referred to in Sentence (1) shall be of noncombustible construction ..." (a),(d) [F03-OS1.2] [F04-OS1.2,OS1.3] (a),(d) [F03-OP1.2] [F04-OP1.2,OP1.3] (b),(d) [F04-OS1.3] (b),(d) [F04-OP1.3] [F04-OS1.3] Applies to portion of Code text: "... c) roof assemblies shall have a fire-resistance rating not less than 1 h ..." and to Clause (d). [F04-OP1.3] Applies to portion of Code text: "... c) roof assemblies shall have a fire-resistance rating not less than 1 h, ..." and to Clause (d). 3.2.2.57. Group D, up to 6 Storeys, Sprinklered, Noncombustible Construction [F02,F04-OS1.2,OS1.3] Applies to portion of Code text: "... a) ... the building is sprinklered throughout ..." (1)[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: "... a) ... the building is sprinklered throughout ..." (2) [F02-OS1.2] Applies to portion of Code text: "... the building referred to in Sentence (1) shall be of noncombustible construction ..." [F02-OP1.2] Applies to portion of Code text: "... the building referred to in Sentence (1) shall be of noncombustible construction ..." (a),(c) [F03-OS1.2] [F04-OS1.2,OS1.3] (a),(c) [F03-OP1.2] [F04-OP1.2,OP1.3] (b),(c) [F04-OS1.3] (b),(c) [F04-OP1.3] 3.2.2.57EMTC. Group D, up to 12 storeys, Sprinklered <u>(b), (c) [F04-OS1.3]</u> (b), (c) [F04-OP1.3] (a), (c) [F03-OS1.2] [F04-OS1.2, OS1.3] (a), (c) [F03-OP1.2] [F04-OP1.2, OP1.3

	Functional Statements and Objectives ⁽¹⁾
322	
(1)	(a) [F02,F04-OS1.2,OS1.3]
(י)	(a) [F02,F04-OP1.2,OP1.3]
(2)	(a),(e) [F03-OS1.2] [F04-OS1.3,OS1.2]
(2)	(a),(e) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(a),(e) [F03-OF 1.2] [F04-OF 1.2,OF 1.3] (b),(d),(e) [F04-OS1.3]
	(b),(d),(e) [F04-OP1.3]
	[F02-OS1.2] Applies to portion of Code text: "c) the roof assembly shall be constructed of <i>noncombustible construction</i> or <i>fire-retardant-treated</i> wood conforming to Article 3.1.4.5.,
	[F02-OP1.2] Applies to portion of Code text: "c) the roof assembly shall be constructed of noncombustible construction or fire-retardant-treated wood conforming to Article 3.1.4.5.,
3.2.2	.59. Group D, up to 4 Storeys, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
(2)	(a),(c) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(c) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(c) [F04-OS1.3]
	(b),(c) [F04-OP1.3]
3.2.2	2.60. Group D, up to 3 Storeys
(2)	[F04-OS1.3] Applies to portion of Code text: " c) roof assemblies shall have, if of <i>combustible construction</i> , a <i>fire-resistance rating</i> not less than 45 min," and to Clause (d).
	[F04-OP1.3] Applies to portion of Code text: " c) roof assemblies shall have, if of <i>combustible construction</i> , a <i>fire-resistance rating</i> not less than 45 min," and to Clause (d).
	(a) [F03-OS1.2] Applies to the requirement that noncombustible floor assemblies be fire separations.
	(a) [F03-OP1.2] Applies to the requirement that noncombustible floor assemblies be fire separations.
	(a),(d) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(d) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(d) [F04-OS1.3]
	(b),(d) [F04-OP1.3]
3.2.2	.61. Group D, up to 3 Storeys, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
(2)	(a) [F03-OS1.2] Applies to the requirement that noncombustible floor assemblies be fire separations.
	(a) [F03-OP1.2] Applies to the requirement that noncombustible floor assemblies be fire separations.
	(a),(c) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(c) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(c) [F04-OS1.3]
	(b),(c) [F04-OP1.3]

Objectives and Functional Statements Attributed to the Acceptable Solutions in Part 3

	Functional Statements and Objectives ⁽¹⁾	
3.2.2	2.62. Group D, up to 2 Storeys	
(2)	(a) [F03-OS1.2] Applies to the requirement that <i>noncombustible</i> floor assemblies be <i>fire separations</i> .	
(-)	(a) [F03-OP1.2] Applies to the requirement that <i>noncombustible</i> floor assemblies be <i>fire separations</i> .	
	[F03-OS1.2] [F04-OS1.2,OS1.3]	
	[F03-OP1.2] [F04-OP1.2,OP1.3]	
3.2.2	2.63. Group D, up to 2 Storeys, Sprinklered	
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the <i>building</i> is <i>sprinklered</i> throughout"	
、/	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the <i>building</i> is <i>sprinklered</i> throughout"	
(2)	(a) [F03-OS1.2] Applies to the requirement that <i>noncombustible</i> floor assemblies be <i>fire separations</i> .	
. ,	(a) [F03-OP1.2] Applies to the requirement that <i>noncombustible</i> floor assemblies be <i>fire separations</i> .	
	[F03-OS1.2] [F04-OS1.2,OS1.3]	
	[F03-OP1.2] [F04-OP1.2,OP1.3]	
3.2.2	2.64. Group E, Any Height, Any Area, Sprinklered	
(2)	[F02-OS1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"	
	[F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"	
	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building shall be sprinklered throughout"	
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building shall be sprinklered throughout"	
	(b),(d) [F03-OS1.2] [F04-OS1.2,OS1.3]	
	(b),(d) [F03-OP1.2] [F04-OP1.2,OP1.3]	
	(c),(d) [F04-OS1.3]	
	(c),(d) [F04-OP1.3]	
3.2.2	2.65. Group E, up to 4 Storeys, Sprinklered	
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"	
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"	
(2)	(a),(c) [F03-OS1.2] [F04-OS1.2,OS1.3]	
	(a),(c) [F03-OP1.2] [F04-OP1.2,OP1.3]	
	(b),(c) [F04-OS1.3]	
	(b),(c) [F04-OP1.3]	
3.2.2	2.66. Group E, up to 3 Storeys	
(2)	(a),(e) [F03-OS1.2] [F04-OS1.2,OS1.3]	
	(a),(e) [F03-OP1.2] [F04-OP1.2,OP1.3]	
	(b),(d) [F04-OS1.3]	
	(b),(d) [F04-OP1.3]	
	(c),(d) [F04-OS1.3]	
	(c),(d) [F04-OP1.3]	

Table 3.10.1.1. (continued) Objectives and Functional Statements Attributed to the Acceptable Solutions in Part 3

	Forming Part of Sentence 3.10.1.1.(1)	
	Functional Statements and Objectives ⁽¹⁾	
3.2.2	.2.2.67. Group E, up to 3 Storeys, Sprinklered	
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the <i>building</i> is <i>sprinklered</i> throughout"	
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"	
(2)	(a),(d) [F03-OS1.2] [F04-OS1.2,OS1.3]	
	(a),(d) [F03-OP1.2] [F04-OP1.2,OP1.3]	
	(b),(c) [F04-OS1.3]	
	(b),(c) [F04-OP1.3]	
3.2.2	2.68. Group E, up to 2 Storeys	
(2)	[F03-OS1.2] [F04-OS1.2,OS1.3]	
	(a),(b) [F03-OP1.2] [F04-OP1.2,OP1.3]	
3.2.2	.69. Group E, up to 2 Storeys, Sprinklered	
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"	
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"	
(2)	[F03-OS1.2] [F04-OS1.2,OS1.3]	
	(a),(b) [F03-OP1.2] [F04-OP1.2,OP1.3]	
3.2.2	.70. Group F, Division 1, up to 4 Storeys, Sprinklered	
(2)	(c),(d) [F04-OP1.3]	
	[F02-OS1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"	
	[F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"	
	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building shall be sprinklered throughout"	
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building shall be sprinklered throughout"	
	(b),(d) [F03-OS1.2] [F04-OS1.2,OS1.3]	
	(b),(d) [F03-OP1.2] [F04-OP1.2,OP1.3]	
	(c),(d) [F04-OS1.3]	
3.2.2		
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"	
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"	
(2)	[F02-OS1.2] Applies to portion of Code text: "The <i>building</i> referred to in Sentence (1) is permitted to be of <i>heavy timber construction</i> or <i>noncombustible construction</i> used singly or in combination"	
	[F02-OP1.2] Applies to portion of Code text: "The <i>building</i> referred to in Sentence (1) is permitted to be of <i>heavy timber construction</i> or <i>noncombustible construction</i> used singly or in combination"	
	[F03-OS1.2] [F04-OS1.2,OS1.3]	
	[F03-OP1.2] [F04-OP1.2,OP1.3]	

Objectives and Functional Statements Attributed to the Acceptable Solutions in Part 3

	Functional Statements and Objectives ⁽¹⁾
3.2.2	2.72. Group F, Division 1, up to 2 Storeys, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
(2)	[F03-OS1.2] Applies to portion of Code text: " a) [noncombustible] floor assemblies shall be fire separations"
	[F03-OP1.2] Applies to portion of Code text: " a) [noncombustible] floor assemblies shall be fire separations"
	[F03-OS1.2] [F04-OS1.2,OS1.3]
	[F03-OP1.2] [F04-OP1.2,OP1.3]
3.2.2	2.74. Group F, Division 2, Any Height, Any Area, Sprinklered
(2)	[F02-OS1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	[F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the <i>building</i> shall be <i>sprinklered</i> throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the <i>building</i> shall be <i>sprinklered</i> throughout"
	(b),(d) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(b),(d) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(c),(d) [F04-OS1.3]
	(c),(d) [F04-OP1.3]
3.2.2	2.75. Group F, Division 2, up to 4 Storeys, Increased Area, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
(2)	[F02-OS1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	[F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	(a),(c) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(c) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(c) [F04-OS1.3]
	(b),(c) [F04-OP1.3]
3.2.2	2.76. Group F, Division 2, up to 3 Storeys
(2)	(a),(e) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(e) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(d) [F04-OS1.3]
	(b),(d) [F04-OP1.3]
	[F04-OS1.3] Applies to portion of Code text: " c) roof assemblies shall have, if of <i>combustible construction</i> , a <i>fire-resistance rating</i> not less than 45 min" and to Clause (d).
	[F04-OP1.3] Applies to portion of Code text: " c) roof assemblies shall have, if of <i>combustible construction</i> , a <i>fire-resistance rating</i> not less than 45 min," and to Clause (d).

	Functional Statements and Objectives ⁽¹⁾
3.2.2	2.77. Group F, Division 2, up to 4 Storeys, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the <i>building</i> is <i>sprinklered</i> throughout"
. /	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the <i>building</i> is <i>sprinklered</i> throughout"
(2)	(a),(d) [F03-OS1.2] [F04-OS1.2,OS1.3]
(_)	(a),(d) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(c) [F04-OS1.3]
	(b),(c) [F04-OP1.3]
3.2.2	2.78. Group F, Division 2, up to 2 Storeys
(2)	(a) [F03-OS1.2] Applies to the requirement that <i>noncombustible</i> floor assemblies be <i>fire separations</i> .
()	(a) [F03-OP1.2] Applies to the requirement that <i>noncombustible</i> floor assemblies be <i>fire separations</i> .
	[F03-OS1.2] [F04-OS1.2,OS1.3]
	[F03-OP1.2] [F04-OP1.2,OP1.3]
3.2.2	.79. Group F, Division 2, up to 2 Storeys, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the <i>building</i> is <i>sprinklered</i> throughout"
()	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the <i>building</i> is <i>sprinklered</i> throughout"
(2)	(a) [F03-OS1.2] Applies to the requirement that <i>noncombustible</i> floor assemblies be <i>fire separations</i> .
(2)	(a) [F03-OP1.2] Applies to the requirement that <i>noncombustible</i> floor assemblies be <i>fire separations</i> .
	[F03-OS1.2] [F04-OS1.2,OS1.3]
	[F03-OP1.2] [F04-OP1.2,OP1.3]
3.2.2	1.80. Group F, Division 3, Any Height, Any Area, Sprinklered
(2)	[F02-OS1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	[F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the <i>building</i> shall be <i>sprinklered</i> throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the <i>building</i> shall be <i>sprinklered</i> throughout"
	(b),(d) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(b),(d) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(c),(d) [F04-OS1.3]
	(c),(d) [F04-OP1.3]
3.2.2	2.81. Group F, Division 3, up to 6 Storeys
(2)	[F02-OS1.2] Applies to portion of Code text: "The building referred to in Sentence (1) shall be of noncombustible construction"
	[F02-OP1.2] Applies to portion of Code text: "The building referred to in Sentence (1) shall be of noncombustible construction"
	(a),(d) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(d) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(d) [F04-OS1.3]
	(b),(d) [F04-OP1.3]
	(c),(d) [F04-OS1.3]
	(c),(d) [F04-OP1.3]

Objectives and Functional Statements Attributed to the Acceptable Solutions in Part 3

	Functional Statements and Objectives ⁽¹⁾
3.2.2	.82. Group F, Division 3, up to 6 Storeys, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
(2)	[F02-OS1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	[F02-OP1.2] Applies to portion of Code text: " the building referred to in Sentence (1) shall be of noncombustible construction"
	(a),(c) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(c) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(c) [F04-OS1.3]
	(b),(c) [F04-OP1.3]
3.2.2	.83. Group F, Division 3, up to 4 Storeys
(2)	[F04-OS1.3] Applies to portion of Code text: " c) roof assemblies shall have, if of <i>combustible construction</i> , a <i>fire-resistance rating</i> not less than 45 min" and to Clause (d).
	[F04-OP1.3] Applies to portion of Code text: " c) roof assemblies shall have, if of <i>combustible construction</i> , a <i>fire-resistance rating</i> not less than 45 min," and to Clause (d).
	(a) [F03-OS1.2] Applies to the requirement that noncombustible floor assemblies be fire separations.
	(a) [F03-OP1.2] Applies to the requirement that noncombustible floor assemblies be fire separations.
	(a),(d) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(d) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(d) [F04-OS1.3]
	(b),(d) [F04-OP1.3]
3.2.2	.84. Group F, Division 3, up to 4 Storeys, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
(2)	(a) [F03-OS1.2] Applies to the requirement that noncombustible floor assemblies be fire separations.
	(a) [F03-OP1.2] Applies to the requirement that noncombustible floor assemblies be fire separations.
	(a),(c) [F03-OS1.2] [F04-OS1.2,OS1.3]
	(a),(c) [F03-OP1.2] [F04-OP1.2,OP1.3]
	(b),(c) [F04-OS1.3]
	(b),(c) [F04-OP1.3]
3.2.2	.85. Group F, Division 3, up to 2 Storeys
(2)	(a) [F03-OS1.2] Applies to the requirement that noncombustible floor assemblies be fire separations.
	(a) [F03-OP1.2] Applies to the requirement that noncombustible floor assemblies be fire separations.
	[F03-OS1.2] [F04-OS1.2,OS1.3]
	[F03-OP1.2] [F04-OP1.2,OP1.3]

	Functional Statements and Objectives ⁽¹⁾
	.86. Group F, Division 3, up to 2 Storeys, Sprinklered
(1)	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the <i>building</i> is <i>sprinklered</i> throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the <i>building</i> is <i>sprinklered</i> throughout"
(2)	(a) [F03-OS1.2] Applies to the requirement that <i>noncombustible</i> floor assemblies be <i>fire separations</i> .
	(a) [F03-OP1.2] Applies to the requirement that <i>noncombustible</i> floor assemblies be <i>fire separations</i> .
	[F03-OS1.2] [F04-OS1.2,OS1.3]
	[F03-OP1.2] [F04-OP1.2,OP1.3]
3.2.2	.87. Group F, Division 3, One Storey
(1)	[F02-OS1.2] Applies to portion of Code text: "A <i>building</i> classified as Group F, Division 3 is permitted to be of <i>heavy timber construction</i> or <i>noncombustible construction</i> used singly or in combination"
	[F02-OP1.2] Applies to portion of Code text: "A <i>building</i> classified as Group F, Division 3 is permitted to be of <i>heavy timber construction</i> or <i>noncombustible construction</i> used singly or in combination"
3.2.2	.88. Group F, Division 3, One Storey, Sprinklered
(1)	[F02-OS1.2] Applies to portion of Code text: "A <i>building</i> classified as Group F, Division 3 is permitted to be of <i>heavy timber construction</i> or <i>noncombustible construction</i> used singly or in combination"
	[F02-OP1.2] Applies to portion of Code text: "A <i>building</i> classified as Group F, Division 3 is permitted to be of <i>heavy timber construction</i> or <i>noncombustible construction</i> used singly or in combination"
	[F02,F04-OS1.2,OS1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
	[F02,F04-OP1.2,OP1.3] Applies to portion of Code text: " a) the building is sprinklered throughout"
3.2.2	.89. Group F, Division 3, One Storey, Any Area, Low Fire Load Occupancy
(2)	[F02-OS1.2]
	[F02-OP1.2]
3.2.2	.90. Group F, Division 3, Storage Garages up to 22 m High
(1)	[F02-OS1.2] Applies to portion of Code text: "A <i>building</i> used as a <i>storage garage</i> with all <i>storeys</i> constructed as <i>open-air storeys</i> and having no other <i>occupancy</i> above it is permitted to have its floor, wall, ceiling and roof assemblies constructed without a <i>fire-resistance rating</i> provided it is: a) of <i>noncombustible construction</i> "
	[F02-OP1.2] Applies to portion of Code text: "A <i>building</i> used as a <i>storage garage</i> with all <i>storeys</i> constructed as <i>open-air storeys</i> and having no other <i>occupancy</i> above it is permitted to have its floor, wall, ceiling and roof assemblies constructed without a <i>fire-resistance rating</i> provided it is: a) of <i>noncombustible construction</i> "
3.2.3	.1. Limiting Distance and Area of Unprotected Openings
(1)	[F03-OP3.1]
(5)	[F03-OP3.1]
(6)	[F03-OP3.1]
(8)	[F03-OP3.1]
(9)	[F03-OP3.1]
(10)	[F03-OP3.1]
	.2. Area of Exposing Building Face
(2)	[F03-OP3.1]
(3)	[F03-OP3.1]
(0)	

	Functional Statements and Objectives ⁽¹⁾		
3.2.3	.4. Party Wall		
(1)	[F03-OP3.1]		
3.2.3	.5. Wall with Limiting Distance Less Than 1.2 m		
(1)	[F03-OP3.1]		
(2)	[F03-OP3.1]		
3.2.3	.6. Combustible Projections		
(1)	[F03-OP3.1]		
(2)	[F03-OP3.1]		
(3)	[F03-OP3.1]		
(5)	[F03-OP3.1]		
3.2.3	.7. Construction of Exposing Building Face		
(1)	[F03,F02-OP3.1]		
(2)	[F03,F02-OP3.1]		
(3)	[F02,F03-OP3.1]		
(4)	[F03,F02-OP3.1]		
3.2.3	.8. Protection of Exterior Building Face		
(1)	[F03,F02-OP3.1]		
3.2.3	.9. Protection of Structural Members		
(1)	[F04-OS1.3]		
	[F04-OP1.3]		
3.2.3	.10. Unlimited Unprotected Openings		
(1)	[F03-OP3.1]		
(2)	[F03-OP3.1]		
3.2.3	.11. Low Fire Load, One Storey Building		
(1)	(b) [F03-OP3.1]		
	(a) [F04-OP3.1]		
3.2.3	.12. Area Increase for Unprotected Openings		
(1)	[F03-OP3.1]		
3.2.3	.13. Protection of Exit Facilities		
(4)	[F06-OS1.2] [F05-OS1.5]		
	[F06-OP1.2]		

	Functional Statements and Objectives ⁽¹⁾
3.2.3	.14. Wall Exposed to Another Wall
(1)	[F03-OS1.2]
	[F03-OP1.2]
	[F03-OP3.1]
(2)	[F03-OS1.2]
	[F03-OP1.2]
	[F03-OP3.1]
3.2.3	.15. Wall Exposed to Adjoining Roof
(1)	[F03-OS1.2]
	[F03-OP1.2]
3.2.3	.16. Protection of Soffits
(1)	[F03-OS1.2]
	[F03-OP1.2]
(2)	[F03-OS1.2]
	[F03-OP1.2]
(3)	[F03-OS1.2]
	[F03-OP1.2]
(4)	[F02-OS1.2]
	[F02-OP1.2]
3.2.3	17. Canopy Protection for Vertically Separated Openings
(1)	[F03-OS1.2]
	[F03-OP1.2]
(2)	[F03-OS1.2]
	[F03-OP1.2]
(3)	[F02-OS1.2]
	[F02-OP1.2]
3.2.3	.18. Covered Vehicular Passageway
(1)	[F03-OP3.1]
(2)	[F02-OP3.1]
3.2.3	.19. Walkway between Buildings
(1)	[F03-OP3.1]
(2)	[F02-OP3.1]
<u>(3</u>) ;	<u>[F02-OP3.1]</u>
	<u>[F02, F12-OP3.1]</u>
(<u>4</u>)	[F02,F12-OP3.1]

Objectives and Functional Statements Attributed to the Acceptable Solutions in Part 3

	Functional Statements and Objectives ⁽¹⁾
3.2.3	3.20. Underground Walkway
(1)	[F01,F02-OP3.1]
(2)	[F03-OP3.1]
(3)	[F02-OP3.1] Applies to portion of Code text: "An underground walkway shall be of noncombustible construction"
	[F80-OP2.3] Applies to portion of Code text: "An underground walkway shall be suitable for an underground location."
(4)	(a) [F05-OS1.5] [F06-OS1.2]
	(b) [F10-OS1.5] [F12-OS1.2]
3.2.3	2.22. Installation of Service Lines Under Buildings
(1)	[F01-OS1.1]
	[F01-OP1.1]
3.2.4	1.1. Determination of Requirement for a Fire Alarm System
(1)	[F11-OS1.5] [F13-OS1.5,OS1.2]
	[F13-OP1.2]
(4)	[F11-OS1.5]
3.2.4	.2. Continuity of Fire Alarm System
(1)	[F11-OS1.5]
(2)	[F11-OS1.5]
(3)	[F11-OS1.5]
(4)	[F10-OS1.5] [F03-OS1.2]
(5)	[F11,F13-OS1.2]
(6)	[F11-OS1.5]
3.2.4	I.3. Types of Fire Alarm Systems
(1)	(a) [F11-OS1.5]
	(b) [F11-OS1.4] [F13-OS1.5]
	(c),(d) [F11-OS1.5]
3.2.4	I.4. Description of Fire Alarm Systems
(1)	[F11-OS1.5]
(2)	(a) [F11-OS1.4] [F13-OS1.5]
	(b),(c) [F11-OS1.5]
(3)	[F13-OS1.5]
(4)	[F13-OS1.5]
3.2.4	I.5. Installation and Verification of Fire Alarm Systems
(1)	[F11,F81-OS1.5] [F13,F12,F81-OS1.5,OS1.2]
	[F12,F11-OS3.7] Applies to voice communication systems.
(2)	[F82-OS1.5]

	Functional Statements and Objectives ⁽¹⁾		
3.2.4	.6. Silencing of Alarm Signals		
(1)	[F11-OS1.5]		
(2)	[F81,F34-OS1.5]		
3.2.4	.7. Signals to Fire Department		
(1)	[F13-OS1.5,OS1.2]		
	[F13-OP1.2]		
(2)	[F13-OS1.5,OS1.2]		
	[F13-OP1.2]		
(3)	[F13-OS1.5,OS1.2]		
	[F13-OP1.2]		
(4)	[F81,F13-OS1.5,OS1.2]		
	[F81,F13-OP1.2]		
(5)	[F13-OS1.5,OS1.2]		
	[F13-OP1.2]		
(6)	[F13-OP1.2]		
	[F13-OS1.2]		
3.2.4	8.8. Annunciator and Zone Indication		
(1)	[F12-OS1.5,OS1.2]		
(2)	[F12-OS1.5,OS1.2]		
(4)	[F12-OS1.2,OS1.5]		
(7)	[F12-OS1.5,OS1.2]		
3.2.4	.9. Electrical Supervision		
(1)	[F82-OS1.5,OS1.2]		
(2)	[F82-OS1.2]		
	[F82-OP1.2]		
(3)	(a),(d),(e),(f),(g) [F82-OS1.2]		
	(a),(d),(e),(f),(g) [F82-OP1.2]		
	(b),(c) [F82-OS1.5]		
(4)	[F81-OP1.2]		
	[F82-OS1.2]		
(5)	[F82-OS1.2]		
	[F82-OP1.2]		
3.2.4	.10. Fire Detectors		
(1)	[F11-OS1.5]		
(2)	[F11-OS1.5]		
(3)	[F02-OS1.2] [F11-OS1.5]		
(4)	[F11-OS1.5]		

	Functional Statements and Objectives ⁽¹⁾		
3.2.4.	11. Smoke Detectors		
(1)	[F11-OS1.5]		
(3)	[F12-OS1.5]		
(4)	[F10-OS1.5]		
(5)	[F11-OS1.5]		
(7)	[F11-OS1.4,OS1.5]		
3.2.4.	12. Prevention of Smoke Circulation		
(1)	[F03-OS1.2]		
3.2.4.	13. Vacuum Cleaning System Shutdown		
(1)	[F03-OS1.2]		
3.2.4.	14. Elevator Emergency Return		
(1)	[F10-OS1.5]		
(2)	[F11-OS1.5]		
(3)	[F02-OS1.2]		
3.2.4.	15. System Monitoring		
(1)	[F11-OS1.5] [F12-OS1.5,OS1.2]		
Î	[F12-OP1.2]		
(2)	[F11-OS1.5] [F13-OS1.5,OS1.2]		
	[F13-OP1.2]		
(3)	[F12-OS1.2,OS1.5]		
	[F12-OP1.2]		
3.2.4.	16. Manual Stations		
(1)	[F11-OS1.5]		
(2)	[F02-OS1.2] [F12-OS1.2,OS1.5] [F10-OS1.5]		
(3)	[F02-OS1.2] [F12-OS1.2,OS1.5] [F10-OS1.5]		
(4)	[F11-OS1.5]		
(5)	[F11-OS1.5]		
3.2.4.	17. Alert and Alarm Signals		
(2)	[F11-OS1.5]		
(3)	[F11-OS1.5]		
3.2.4.	3.2.4.18. Audibility of Alarm Systems		
(1)	[F11-OS1.5]		
(2)	[F11-OS1.5]		
(3)	[F11-OS1.5]		
(4)	[F33-OS3.5]		
(5)	[F11-OS1.5]		
(6)	[F11-OS1.5]		

	Functional Statements and Objectives ⁽¹⁾		
(7)	[F11,F81-OS1.5]		
(8)	[F11,F81-OS1.5]		
(9)	[F11,F81-OS1.5]		
(10)	[F11-OS1.5]		
(12)	[F11-OS1.5]		
3.2.4.	19. Visible Signal Devices and Visible Warning Systems		
(1)	[F11-OS1.5]		
(2)	[F11-OS1.5]		
(4)	[F11, F81-OS1.5]		
(5)	[F11, F81-OS1.5]		
	20. Smoke Alarms		
(2)	[F81,F11-OS1.5]		
(3)	[F11-OS1.5]		
(4)	[F11-OS1.5]		
(5)	[F11-OS1.5]		
(6)	[F11-OS1.5]		
(7)	[F11,F81-OS1.5]		
(8)	[F11,F81-OS1.5]		
(10)	[F11-OS1.5]		
(11)	[F81,F11-OS1.5]		
(12)	[F11,F81-OS1.5]		
(14)	[F11-OS1.5]		
3.2.4.	21. Residential Fire Warning Systems		
(1)	[F81,F11-OS1.5]		
3.2.4.	22. Voice Communication Systems		
(1)	[F12,F11-OS3.7]		
(2)	[F11-OS1.5]		
(3)	[F11-OS1.5] [F13-OS1.4,OS1.5]		
(4)	[F11-OS1.5]		
(5)	[F12-OS3.7]		
(6)	[F11-OS1.5]		
(7)	[F11-OS1.5]		
(8)	[F11-OS1.5]		
(9)	[F11-OS1.5]		

	Functional Statements and Objectives ⁽¹⁾		
3.2 5	5.1. Access to Above-Grade Storeys		
(1)	[F12-OS1.5,OS1.2]		
(')	[F12-OP1.2]		
(2)	[F12-OS1.5,OS1.2]		
(2)	[F12-OP1.2]		
(2)	[F12-OS1.5,OS1.2]		
(3)			
2.2.6	[F12-OP1.2] 5.2. Access to Basements		
	-		
(1)	[F12-OS1.5,OS1.2]		
(0)	[F12-OP1.2]		
(2)	[F12-OS1.5,OS1.2]		
	[F12-OP1.2]		
-	5.3. Roof Access		
(1)	[F12-OS1.2]		
	[F12-OP1.2]		
3.2.5.4. Access Routes			
(1)	[F12-OS1.5,OS1.2]		
	[F12-OP1.2]		
3.2.5	5.5. Location of Access Routes		
(1)	[F12-OS1.5,OS1.2] [F06-OS1.1]		
	[F12-OP1.2]		
(2)	[F12-OS1.2]		
	[F12-OP1.2]		
(4)	[F12-OS1.2]		
	[F12-OP1.2]		
3.2.5	5.6. Access Route Design		
(1)	[F12-OS1.2]		
	[F12-OP1.2]		
(2)	[F02,F12-OS1.2]		
	[F02,F12,F03-OP1.2]		
	[F02,F12,F03-OP3.1]		
3.2.5	5.7. Water Supply		
(1)	[F02-OS1.2]		
	[F02-OP1.2]		
	[F02-OP3.1]		

	8. Standpipe Systems
(4)	
(1)	[F02-OS1.2]
f	[F02-OP1.2]
3.2.5.9). Standpipe System Design
(1)	[F02-OS1.2]
f	[F02-OP1.2]
(2)	[F12-OS1.2]
f	[F12-OP1.2]
(5)	[F02-OS1.2]
f	[F02-OP1.2]
(6)	[F12-OS1.2]
Ī	[F12-OP1.2]
3.2.5.1	0. Hose Connections
(1)	[F03-OS1.2] [F05,F06-OS1.5,OS1.2]
f	[F03,F06-OP1.2]
(3)	[F12-OS1.2]
Ī	[F12-OP1.2]
(4)	[F02-OS1.2]
ſ	[F02-OP1.2]
3.2.5.1	1. Hose Stations
(1)	[F02-OS1.2]
ſ	[F02-OP1.2]
(2)	[F02-OS1.2]
ſ	[F02-OP1.2]
(3)	[F02,F12-OS1.2]
ſ	[F02,F12-OP1.2]
(4)	[F03-OS1.2]
Ī	[F03-OP1.2]
(5)	[F10-OS1.5]
(6)	[F02-OS1.2]
ſ	[F02-OP1.2]
(7)	[F01-OS1.1]
3.2.5.1	2. Automatic Sprinkler Systems
(1)	[F02,F81,F82-OS1.2]
Ī	[F02,F81,F82-OP1.2]
(2)	[F02,F81-OS1.2]
Ī	[F02,F81-OP1.2]

(0)	Functional Statements and Objectives ⁽¹⁾		
(3)	[F02,F81-OS1.2]		
	[F02,F81-OP1.2]		
(4)	[F02-OS1.2]		
	[F02-OP1.2]		
(5)	[F81-OS1.2]		
	[F81-OP1.2]		
(6)	[F02-OS1.2]		
	[F02-OP1.2]		
(7)	[F03-OS1.2]		
	[F03-OP1.2]		
	[F03-OP3.1]		
(8)	[F81-OS3.3,OS3.6]		
3.2.5	13. Combustible Sprinkler Piping		
(2)	[F02,F81-OS1.2]		
	[F02,F81-OP1.2]		
(3)	[F06-OS1.2]		
	[F06-OP1.2]		
(4)	[F06-OS1.2]		
	[F06-OP1.2]		
3.2.5	.14. Sprinklered Service Space		
(1)	[F02-OS1.2]		
	[F02-OP1.2]		
(2)	[F12-OS1.2]		
	[F12-OP1.2]		
(3)	[F11-OS1.5] [F12-OS1.5,OS1.2]		
	[F12-OP1.2]		
3.2.5	.15. Fire Department Connections		
(1)	[F12-OS1.2]		
	[F12-OP1.2]		
(2)	[F12-OS1.2]		
	[F12-OP1.2]		
3.2.5	16. Portable Fire Extinguishers		
(1)	[F02,F12,F81-OS1.2]		
	[F02,F12,F81-OP1.2]		
(2)	[F12-OS1.2]		
	[F12-OP1.2]		
	I		

	Functional Statements and Objectives ⁽¹⁾
3.2.5	i.17. Protection from Freezing
(1)	[F81-OS1.2]
	[F81-OP1.2]
3.2.5	i.18. Fire Pumps
(1)	[F02,F81-OS1.2] [F81-OS1.4]
	[F02,F81-OP1.2] [F81-OP1.4]
3.2.6	5.2. Limits to Smoke Movement
(1)	[F02-OS1.2,OS1.5]
	[F02-OP1.2]
(2)	[F06-OS1.2,OS1.5] [F05-OS1.5]
	[F06-OP1.2]
(3)	[F06-OS1.5,OS1.2] [F05-OS1.5]
	[F06-OP1.2]
(4)	[F03-OS1.2,OS1.5]
	[F03-OP1.2]
(5)	[F03-OS1.2,OS1.5]
	[F03-OP1.2]
(6)	[F03,F12-OS1.2,OS1.5]
	[F03,F12-OP1.2]
3.2.6	.3. Connected Buildings
(1)	[F03-OS1.2,OS1.5]
	[F03-OP1.2]
	[F03-OP3.1]
3.2.6	.4. Emergency Operation of Elevators
(1)	[F12-OS1.2,OS1.5]
	[F12-OP1.2]
(2)	[F12-OS1.2,OS1.5]
	[F12-OP1.2]
(3)	[F12-OS1.2,OS1.5]
	[F12-OP1.2]
(4)	[F12-OS1.2,OS1.5]
	[F12-OP1.2]
3.2.6	.5. Elevator for Use by Firefighters
(1)	[F12,F06-OS1.2,OS1.5]
	[F12,F06-OP1.2]
(2)	[F12-OS1.2,OS1.5]
	[F12-OP1.2]

	Eurotional Statements and Objectives(1)
(0)	Functional Statements and Objectives ⁽¹⁾
(3)	[F06-OS1.2,OS1.5]
	[F06-OP1.2]
(4)	[F12-OS1.2,OS1.5]
	[F12-OP1.2]
(5)	[F12-OS1.2,OS1.5]
	[F12-OP1.2]
(6)	[F06-OS1.2,OS1.5]
)	[F06-OP1.2]
3.2.6.	.6. Venting to Aid Firefighting
(1)	[F06-OS1.2,OS1.5]
ĺ	[F06-OP1.2]
(2)	[F30-OS3.1]
(3)	[F12-OS1.2,OS1.5]
ĺ	[F12-OP1.2]
(4)	[F03-OS1.2] [F12-OS1.2,OS1.5]
3.2.6.	7. Central Alarm and Control Facility
(1)	[F12-OS1.2,OS1.5]
1	[F12-OP1.2]
(2)	[F12-OS1.2,OS1.5] [F11-OS1.5]
1	[F12-OP1.2]
3.2.6.	8. Voice Communication System
(1)	[F12,F11-OS3.7]
3.2.6.	9. Testing
(1)	[F82-OS1.2,OS1.5]
1	[F82-OP1.2]
3.2.7.	1. Minimum Lighting Requirements
(1)	[F30-OS3.1] [F10-OS3.7]
(2)	[F30-OS3.1] [F10-OS3.7]
3.2.7.	2. Recessed Lighting Fixtures
(1)	[F01-OS1.1,OS1.2]
•	[F01-OP1.1,OP1.2]
3.2.7.	3. Emergency Lighting
(1)	[F30-OS3.1] [F10-OS3.7]
(2)	[F30-OS3.1] [F10-OS3.7]
(3)	[F30-OS3.1] [F10-OS3.7]
(4)	[F30-OS3.1] [F10-OS3.7]

	Functional Statements and Objectives ⁽¹⁾	
3.2.7	7.4. Emergency Power for Lighting	
(1)	[F30-OS3.1] [F10-OS3.7]	
(2)	[F30,F81-OS3.1] [F10,F81-OS3.7]	
3.2.7	7.5. Emergency Power Supply Installation	
(1)	[F81,F06,F11,F02,F03,F10,F12-OS1.2,OS1.5]	
	[F81,F06,F02,F03-OP1.2]	
	[F81,F06,F02-OP3.1]	
	[F81,F30-OS3.1] [F81,F11,F10,F12-OS3.7]	
3.2.7	7.6. Emergency Power for Treatment Occupancies	
(1)	[F81,F06,F11,F02,F03,F10,F12-OS1.2,OS1.5]	
	[F81,F06,F02,F03-OP1.2]	
	[F81,F06,F02-OP3.1]	
	[F81,F30-OS3.1] [F81,F11,F10,F12-OS3.7]	
3.2.7	7.7. Fuel Supply Shut-off Valves	
(1)	[F12-OS1.1,OS1.2] Applies to the requirement for a suitably identified shut-off valve outside the building.	
	[F12-OP1.2] Applies to the requirement for a suitably identified shut-off valve outside the <i>building</i> .	
	[F12-OH5] Applies to the requirement for a suitably identified shut-off valve outside the <i>building</i> .	
	[F81-OS1.2,OS1.5] Applies to the requirement for a suitably identified separate shut-off valve.	
	[F81-OS3.1,OS3.7] Applies to the requirement for a suitably identified separate shut-off valve.	
3.2.7	.8. Emergency Power for Fire Alarm Systems	
(1)	[F11-OS1.5] [F13-OS1.5,OS1.2]	
	[F13-OP1.2] Applies to the requirement for fire alarm systems, including those with a voice communication system, to be provided with an emergency power supply.	
(2)	[F11-OS1.5] [F13-OS1.2,OS1.5]	
	[F13-OP1.2]	
(3)	[F11-OS1.5] [F13-OS1.5,OS1.2]	
	[F13-OP1.2]	
(4)	[F13-OP1.2]	
	[F11-OS1.5] [F13-OS1.2,OS1.5]	
3.2.7	.9. Emergency Power for Building Services	
(1)	[F12,F02,F03-OS1.5,OS1.2]	
	[F12,F02,F03-OP1.2]	
	(b) [F02-OP3.1]	
	(a) [F36-OS3.6] [F12,F10-OS3.7]	
(2)	[F12-OS1.5,OS1.2]	
	[F12-OP1.2]	
	[F36-OS3.6] [F12-OS3.7]	

	Functional Statements and Objectives ⁽¹⁾
3.2.7	.10. Protection of Electrical Conductors
(2)	[F06-OS1.2,OS1.5]
. ,	[F06-OP1.2]
(3)	[F06-OS1.2,OS1.5]
. ,	[F06-OP1.2]
(4)	[F06-OS1.2,OS1.5]
	[F06-OP1.2]
(6)	[F06-OS1.2,OS1.5]
	[F06-OP1.2]
(8)	[F06-OS1.2,OS1.5]
	[F06-OP1.2]
(10)	[F06-OS1.4]
	[F06-OP1.2]
	[F10-OS3.7]
3.2.8	.1. Application
(1)	[F03,F06-OS1.2] [F05-OS1.5]
	[F03,F06-OP1.2]
3.2.8	.2. Exceptions to Special Protection
(3)	[F03-OS1.2]
	[F03-OP1.2]
(5)	[F02,F03-OS1.2]
	[F02,F03-OP1.2]
3.2.8	.3. Sprinklers
(1)	[F02-OS1.2]
	[F02-OP1.2]
3.2.8	.4. Vestibules
(1)	[F06-OS1.2] [F05-OS1.5]
	[F06,F03-OP1.2]
3.2.8	.5. Protected Floor Space
(1)	[F05-OS1.2] [F06-OS1.5]
3.2.8	.6. Draft Stops
(1)	[F02-OS1.2] [F11-OS1.5] [F13-OS1.5,OS1.2]
	[F02,F13-OP1.2]

	Functional Statements and Objectives ⁽¹⁾		
3.2.8	3.7. Mechanical Exhaust System		
(1)	[F03-OS1.5,OS1.2]		
	[F03-OP1.2]		
(2)	[F12-OS1.5,OS1.2]		
	[F12-OP1.2]		
3.2.8	8.8. Combustible Content Limits		
(1)	[F02-OS1.2]		
	[F02-OP1.2]		
3.2.9	.1. Testing		
(1)	[F02,F81,F82-OS1.2,OS1.5]		
	[F02,F81,F82-OP1.2]		
3.3.1	.1. Separation of Suites		
(1)	[F03-OS1.2]		
	[F03-OP1.2]		
(3)	[F02-OS1.2]		
	[F02-OP1.2]		
3.3.1	.2. Hazardous Substances, Equipment and Processes		
(1)	[F01,F02,F03-OS1.1,OS1.2]		
	[F01,F02,F03-OP1.1,OP1.2]		
	[F43-OS3.4]		
(3)	[F43-OS3.7]		
	[F05-OS1.5]		
3.3.1	.3. Means of Egress		
(3)	[F10-OS3.7]		
(4)	[F10,F12,F05,F06-OS3.7]		
(5)	[F10,F12-OS3.7]		
(6)	[F10,F12,F05,F06-OS3.7]		
(7)	[F10,F12,F05,F06-OS3.7]		
(8)	[F05-OS1.5]		
(9)	[F10,F12,F05,F06-OS3.7]		
3.3.1	.4. Public Corridor Separations		
(1)	[F03,F05-OS1.5] [F06-OS1.5,OS1.2]		
	[F03,F06-OP1.2]		
(2)	[F03,F05-OS1.5] [F06-OS1.5,OS1.2]		
	[F03,F06-OP1.2]		
(3)	[F03,F05-OS1.5] [F06-OS1.2,OS1.5]		
	[F03,F06-OP1.2]		

	Functional Statements and Objectives ⁽¹⁾		
(4)	(a),(b) [F03,F05,F10-OS1.5] [F06,F12-OS1.2,OS1.5]		
	(c) [F03,F05-OS1.5] [F03,F06-OS1.5,OS1.2]		
	(a),(b) [F03,F06,F12-OP1.2] (c) [F03,F06-OP1.2]		
3.3.1	.5. Egress Doorways		
(1)	[F10,F05-OS1.5]		
(2)	[F05,F10-OS1.5]		
3.3.1	.6. Travel Distance		
(1)	[F10-OS1.5]		
3.3.1	.7. Protection on Accessible Floor Areas		
(1)	[F10,F05-OS1.5]		
	(a) [F06-OS1.5]		
(2)	[F03-OS1.2] [F06-OS1.5]		
(4)	(a) [F10,F73-OS1.5]		
	(b),(c) [F10-OS1.5]		
3.3.1	.9. Corridors		
(1)	[F10,F12-OS3.7]		
(2)	[F10,F12-OS3.7]		
(3)	[F30,F73-OS3.1]		
(5)	[F10,F12-OS3.7]		
(6)	(a) [F10,F12-OS3.7]		
	(b) [F05-OS1.5] [F06-OS1.5,OS1.2]		
3.3.1	.11. Door Swing		
(1)	[F10-OS3.7]		
(2)	[F10-OS3.7]		
(3)	[F10-OS3.7]		
(4)	[F10-OS3.7]		
3.3.1	.12. Sliding Doors		
(1)	(b) [F10-OS3.7]		
3.3.1	.13. Doors and Door Hardware		
(1)	(a),(b) [F10,F12-OS3.7]		
	(c) [F10-OS3.7] [F30-OS3.1]		
	(<u>d) [F30-OS3.1]</u>		
(2)	[F30-OS3.1] [F10-OS3.7]		
(3)	[F10-OS3.7]		
(4)	[F10-OS3.7]		

	Functional Statements and Objectives ⁽¹⁾	
(5) [F10-OS3.7]		
. ,	[F73-OA1]	
(8)	[F12-OS3.7]	
(9)	[F12-OS3.7]	
(10)	[F12-OS3.7]	
<u>(11)</u> §	<u>9F30-OS3.11</u>	
$\sim \sim \sim \sim$	16. Tapered Treads in a Curved Flight	
(2)	[F30-OS3.1] [F10-OS3.7]	
(3)	[F30-OS3.1] [F10-OS3.7]	
(4)	[F30-OS3.1] [F10-OS3.7]	
3.3.1.	17. Capacity of Access to Exits	
(2)	[F10-OS3.7]	
(3)	[F10-OS3.7]	
(4)	[F10-OS3.7]	
(6)	[F10-OS3.7]	
3.3.1.	18. Guards	
(1)	[F30-OS3.1]	
(2)	[F30-OS3.1]	
(3)	[F30-OS3.1]	
(4)	[F30-OS3.1]	
3.3.1.	19. Transparent Doors and Panels	
(1)	[F30-OS3.1] [F10-OS3.7]	
(2)	[F30-OS3.1] [F10-OS3.7]	
(3)	[F20-OS3.1]	
(4)	[F30-OS3.1] [F10-OS3.7]	
(6)	[F30-OS3.1] [F10-OS3.7]	
(8)	[F30-OS3.1]	
3.3.1.	20. Exhaust Ventilation and Explosion Venting	
(1)	[F01-OS1.1]	
(2)	(a) [F02-OS1.2]	
	(a) [F02-OP1.2]	
(3)	[F02-OS1.3] Applies to the requirement for explosion-relief devices and vents.	
ļ	[F02-OP1.3] Applies to the requirement for explosion-relief devices and vents.	

Functional Statements and Objectives ⁽¹⁾
.21. Janitors' Rooms
[F03-OS1.2]
[F03-OP1.2]
[F02-OS1.2]
[F02-OP1.2]
.22. Common Laundry Rooms
[F03-OS1.2]
[F03-OP1.2]
[F02-OS1.2]
[F02-OP1.2]
.23. Obstructions
[F10-OS3.7]
.24. Signs in Service Spaces
[F10-OS3.7]
.25. Welding and Cutting
[F03,F02-OS1.2]
[F03,F02-OP1.2]
I.1. Scope
[F30-OS3.1] [F10-OS3.7]
[F30-OS3.1] [F10-OS3.7]
.2. Fire Separations
[F03-OS1.2]
[F03-OS1.2] Applies where space under tiers of seats is not sprinklered.
[F03-OS1.2] Applies where space under tiers of seats is <i>sprinklered</i> .
.4. Fixed Seats
[F30-OS3.1] [F10-OS3.7]
[F10-OS3.7]
.5. Aisles
[F10-OS3.7]
[F10-OS3.7] [F30-OS3.1]
[F10-OS3.7] [F30-OS3.1]
[F10-OS3.7] [F30-OS3.1]
[F10-OS3.7] [F30-OS3.1]

	Functional Statements and Objectives ⁽¹⁾		
(12)	[F10-OS3.7] [F30-OS3.1]		
(13)	[F10-OS3.7] [F30-OS3.1]		
(14)	[F10-OS3.7] [F30-OS3.1]		
(15)	[F10-OS3.7] [F30-OS3.1]		
(16)	[F10-OS3.7] [F30-OS3.1]		
	6. Corridors		
(1)	[F03,F05-OS1.5] [F06-OS1.5,OS1.2]		
	[F03,F06-OP1.2]		
(3)	[F03,F05-OS1.5] [F06-OS1.5,OS1.2]		
	[F03,F06-OP1.2]		
(4)	[F10-OS3.7]		
	7. Doors		
(1)	[F10-OS3.7]		
3.3.2.	8. Fixed Bench-Type Seats without Arms		
(1)	[F10-OS3.7]		
	[F10-OS3.7]		
3.3.2.	10. Handrails in Aisles with Steps		
(1)	[F30-OS3.1] [F10-OS3.7]		
(2)	[F30-OS3.1] [F10-OS3.7]		
3.3.2.	11. Outdoor Places of Assembly		
(1)	[F10-OS3.7]		
(2)	[F10-OS3.7]		
(3)	[F10-OS3.7]		
(5)	[F10-OS3.7]		
3.3.2.	12. Bleachers		
(1)	[F10-OS3.7] [F30-OS3.1]		
(2)	[F10-OS3.7] [F30-OS3.1]		
(4)	[F10-OS3.7] [F30-OS3.1]		
(5)	[F30-OS3.1]		
3.3.2.	13. Libraries		
(1)	[F03-OS1.2]		
	[F03-OP1.2]		
(2)	[F02-OS1.2]		
	[F02-OP1.2]		

	Functional Statements and Objectives ⁽¹⁾	
3.3.2	. 14. Stages for Theatrical Performances	
(1)	[F02-OS1.2]	
(.)	[F02-OP1.2]	
(2)	[F03-OS1.2]	
(2)	[F03-OP1.2]	
(3)	[F03-OS1.2]	
(0)	[F03-OP1.2]	
(4)	[F03-OS1.2]	
(4)	[F03-OP1.2]	
(E)		
(5)	[F02-OS1.2] [F06-OS1.2,OS1.5]	
(0)	[F02,F06-OP1.2]	
(6)	[F03-OS1.2,OS1.5]	
	[F03-OP1.2]	
	2.15. Risers for Stairs	
(1)	[F30-OS3.1]	
-	2.16. Storage Rooms	
(1)	[F12-OS1.2]	
	[F12-OP1.2]	
3.3.2	2.17. Daycare Facilities with Children under 30 Months	
(1)	(a) [F02,F03,F05-OS1.2,OS1.3]	
	(b) [F10-OS1.5]	
(2)	[F11-OS1.5]	
(3)	[F11-OS1.5]	
(4)	[F11-OS1.5]	
	[F81-OS1.4]	
(5)	[F11-OS1.5]	
	[F81-OS1.4]	
3.3.3	.2. Separations between Care, Treatment or Detention Occupancies and Repair Garages	
(1)	[F44-OS3.4]	
	[F03-OS1.2]	
3.3.3	3.3. Corridors	
(1)	[F10-OS3.7]	
(2)	[F10-OS3.7]	
(3)	[F10,F12-OS3.7]	
(4)	(a) [F10-OS3.7]	
	(b) [F10,F12-OS3.7]	

	Functional Statements and Objectives ⁽¹⁾
3.3.3	4. Doorway Width
(1)	[F10,F12-OS3.7]
(2)	[F10,F12-OS3.7]
3.3.3	5. Compartments and Fire Separations
(2)	[F05-OS1.5] [F06-OS1.5,OS1.2]
	[F06-OP1.2]
(4)	[F05-OS1.2] [F06-OS1.2,OS1.5]
	[F03,F06-OP1.2]
(6)	[F10-OS1.5]
(7)	[F10-OS1.5]
(8)	[F03,F05-OS1.2] [F06-OS1.5]
(12)	[F03,F05-OS1.2] [F06-OS1.5]
(16)	[F02,F03-OS1.2] [F44-OS1.1]
	[F02,F03-OP1.2]
3.3.3	6. Areas of Refuge
(1)	[F03-OS1.2]
3.3.3	7. Contained Use Areas
(2)	[F03-OS1.2] [F06-OS1.5,OS1.2]
	[F03,F06-OP1.2]
(3)	[F02-OS1.2] [F06-OS1.5,OS1.2]
	[F02,F06-OP1.2]
(4)	[F02-OS1.2] [F06-OS1.5,OS1.2]
	[F02,F06-OP1.2]
(5)	[F10-OS3.7]
3.3.4	2. Fire Separations
(1)	[F03-OS1.2] [F05-OS1.5] [F06-OS1.5,OS1.2]
	[F03,F06-OP1.2]
(4)	[F02,F03-OS1.2] [F44-OS1.1]
	(a),(b) [F02,F03-OP1.2]
(5)	[F03-OS1.2] [F01-OS1.1]
	(a) [F03-OP1.2]
	[F44-OS3.4]

	Functional Statements and Objectives ⁽¹⁾
334	3. Storage Rooms
(1)	[F02-OS1.2]
(')	[F02-OP1.2]
(2)	[F03-OS1.2]
(2)	[F03-OP1.2]
(4)	[F12-OS1.2]
(ד)	[F12-OP1.2]
331	4. Egress from Dwelling Units
(2)	[F10,F05-OS3.7]
(2)	[F10-OS3.7]
(3)	[F05-OS1.2,OS1.5]
	[F10,F05-OS3.7]
(5)	
(6)	[F10,F05-OS3.7] 5. Automatic Locking Prohibition
(1)	[F10-OS3.7]
	8. Protection of Openable Windows
(1)	[F30-OS3.1]
	2. Fire Extinguishing Systems
(1)	[F03-OS1.2]
	[F03-OP1.2]
	3. Basements
(1)	[F12-OS1.2,OS1.5] [F01-OS1.1]
	[F12-OP1.2]
(2)	[F06-OS1.5,OS1.2] Applies to the separation of entrances to <i>basements</i> and to rooms containing <i>building</i> services from the remainder of the <i>building</i> .
	[F06-OP1.2] Applies to the separation of entrances from the remainder of the <i>building</i> .
	[F05-OS1.5] [F06-OS1.2,OS1.5] Applies to the separation of <i>exits</i> from the remainder of the <i>building</i> .
	[F06-OP1.2] Applies to the separation of <i>exits</i> from the remainder of the <i>building</i> .
(3)	[F44-OS1.1]
3.3.5	4. Repair and Storage Garages
(2)	[F30-OS3.1] [F10,F12-OS3.7]
(5)	[F30-OS3.1]
(6)	[F30-OS3.1]
(8)	[F02-OS1.2]
	[F02-OP1.2]
3.3.5	5. Repair Garage Separation
(1)	[F03-OS1.2]
	[F03-OP1.2]

	Functional Statements and Objectives ⁽¹⁾	
3.3.5	3.3.5.6. Storage Garage Separation	
(1)	[F03-OS1.2]	
	[F03-OP1.2]	
3.3.5	5.7. Vestibules	
(4)	[F44-OS3.4]	
	[F44-OS1.1]	
3.3.5	i.8. Dispensing of Fuel	
(1)	[F01-OS1.1]	
(2)	[F01-OS1.1]	
3.3.5	.9. Multiple-Tenant Self-Storage Warehouses	
(1)	[F03-OS1.2]	
	[F03-OP1.2]	
3.3.6	.2. Storage of Dangerous Goods	
(1)	[F03-OP1.2]	
	[F03-OS1.2]	
(2)	[F03-OS1.2]	
	[F03-OP1.2]	
(3)	[F01,F02,F03,F81-OS1.1,OS1.2]	
(4)	[F01-OS1.1]	
	[F01-OP1.1]	
3.3.6	.3. Indoor Storage of Anhydrous Ammonia and Flammable, Toxic and Oxidizing Gases	
(1)	(a) [F03-OS1.2] [F44-OS1.1]	
	(a) [F03-OP1.2]	
	(a) [F44-OS1.2,OS1.5,OS1.1] Applies to gas-tight fire separations.	
	(b) [F12-OS1.2] [F01-OS1.1] [F02-OS1.3]	
	(b) [F02-OP1.3]	
	(c) [F12-OS1.1]	
	(d) [F44-OS1.1]	
(2)	(a) [F03-OP1.2]	
	(a) [F03-OS1.2] [F44-OS1.1]	
	(a) [F44-OS1.2,OS1.5,OS1.1] Applies to gas-tight fire separations.	
	(b) [F12-OS1.2] [F01-OS1.1]	
	(c) [F12-OS1.1]	
	(d) [F44-OS1.1]	

	Functional Statements and Objectives ⁽¹⁾	
3.3.6	.4. Storage and Dispensing Rooms for Flammable Liquids and Combustible Liquids	
(1)	[F03-OS1.2]	
(.)	[F03-OP1.2]	
(2)	[F02-OS1.3]	
(2)	[F02-OP1.3]	
336	1.5. Tire Storage	
(1)	[F03-OS1.2]	
(1)	[F03-OP1.2]	
226	i.6. Ammonium Nitrate Storage	
(2)	[F01-OS1.1] [F02,F12-OS1.2]	
(0)	[F01-OP1.1] [F02,F12-OP1.2]	
(3)	[F03-OS1.2] [F01-OS1.1]	
	[F03-OP1.2] [F01-OP1.1]	
(4)	[F12,F02-OS1.1]	
	[F12,F02-OP1.2]	
(5)	[F44-OH5]	
	[F01-OS1.1] [F02-OS1.2]	
	[F43-OS3.4]	
(6)	[F01,F81-OS1.1]	
3.3.6	7. Flooring Materials	
(1)	[F43-OS3.4]	
	[F44-OH5]	
	[F01-OS1.1]	
3.3.6	.8. Fire Separations in Process Plants	
(1)	[F03-OP1.2]	
	[F03-OS1.2]	
3.3.6	.9. Basements and Pits	
(1)	[F01-OS1.1]	
	[F01-OP1.1]	
3.4.1	.2. Separation of Exits	
(1)	[F10,F12,F05,F06-OS3.7]	
	[F12,F06-OP1.2]	
	[F12,F06-OS1.5,OS1.2]	
(2)	[F10-OS3.7]	
	.5. Exterior Exit Passageways	
(1)	[F10-OS3.7]	
. /		

	Functional Statements and Objectives ⁽¹⁾
3.4.1	.6. Restricted Use of Horizontal Exits
(1)	[F10-OS3.7]
(2)	[F10,F05-OS3.7]
	.7. Slide Escapes
(1)	[F10-OS3.7]
	.9. Mirrors near Exits
(1)	[F10-OS3.7] [F30-OS3.1]
	.10. Combustible Glazing in Exits
(1)	[F05-OS1.2] [F06-OS1.2,OS1.5]
	[F03,F06-OP1.2]
3.4.2	1. Minimum Number of Exits
(1)	[F10,F12,F05,F06-OS3.7]
	[F12,F06-OS1.2]
	[F12,F06-OP1.2]
(3)	[F10-OS3.7]
	.2. Means of Egress from Mezzanines
(1)	[F05-OS1.5]
	.3. Distance between Exits
(1)	[F10,F05-OS1.5]
(4)	[F10-OS3.7]
3.4.2	.4. Travel Distance
(3)	[F10-OS3.7]
3.4.2	.5. Location of Exits
(1)	[F10-OS3.7]
(3)	[F10-OS3.7]
3.4.2	.6. Principal Entrances
(1)	[F10-OS3.7]
(2)	[F10-OS3.7]
3.4.3	1. .1. Exit Width Based on Occupant Load
(2)	[F10-OS3.7]
3.4.3	2. Exit Width
(1)	[F10-OS3.7]
(2)	[F10-OS3.7]
(3)	[F10-OS3.7]
(6)	[F10-OS3.7]
(7)	[F10-OS3.7]

Functional Statements and Objectives ⁽¹⁾	
[F12,F10-OS3.7] [F30-OS3.1]	
[F12-OP1.2]	
[F12-OS1.2]	
3.3. Exit Width Reduction	
[F10,F12-OS3.7] [F30-OS3.1]	
[F12-OP1.2]	
[F12-OS1.2]	
[F10,F12-OS3.7]	
[F12-OP1.2]	
[F12-OS1.2]	
[F10,F12-OS3.7]	
[F12-OP1.2]	
[F12-OS1.2]	
[F10,F12-OS3.7]	
[F12-OP1.2]	
[F12-OS1.2]	
8.4. Headroom Clearance	
[F30-OS3.1] [F10,F12-OS3.7]	
[F12-OP1.2]	
[F12-OS1.2]	
[F30-OS3.1] [F10,F12-OS3.7]	
[F12-OP1.2]	
[F12-OS1.2]	
[F30-OS3.1] [F10,F12-OS3.7]	
[F12-OP1.2]	
[F12-OS1.2]	
I.1. Fire-Resistance Rating of Exit Separations	
[F05-OS1.5] [F06-OS1.5,OS1.2] [F03-OS1.2]	
[F06,F03-OP1.2]	
I.2. Exits through Lobbies	
[F05,F06-OS1.5]	
[F12,F10,F05,F06-OS1.5]	
I.3. Exterior Passageway Exceptions	
[F05,F06,F10-OS1.5]	

	Functional Statements and Objectives ⁽¹⁾	
3.4.4	.4. Integrity of Exits	
(1)	[F05-OS1.5] [F06-OS1.5,OS1.2] [F03-OS1.2]	
()	[F06,F03-OP1.2]	
(2)	[F05-OS1.5] [F06-OS1.5,OS1.2]	
()	[F06-OP1.2]	
(3)	[F05-OS1.5] [F06-OS1.5,OS1.2]	
. ,	[F06-OP1.2]	
(4)	[F05-OS1.5] [F06-OS1.5,OS1.2]	
()	[F06-OP1.2]	
	[F43-OS3.7]	
(5)	[F05-OS1.5] [F06-OS1.5,OS1.2] [F03-OS1.2]	
. ,	[F03,F06-OP1.2]	
(6)	[F10,F12-OS3.7] [F30-OS3.1] [F31-OS3.2] [F32-OS3.3] [F43-OS3.4]	
	[F10,F05-OS1.5] [F12-OS1.5,OS1.2]	
	[F12-OP1.2]	
(7)	[F05-OS1.5] [F06-OS1.5,OS1.2]	
	[F06-OP1.2]	
	[F43-OS3.7]	
(8)	[F05-OS1.5] [F06-OS1.5,OS1.2]	
	[F06-OP1.2]	
(9)	[F05-OS1.5] [F06-OS1.5,OS1.2]	
	[F06-OP1.2]	
3.4.5	.1. Exit Signs	
(1)	[F10-OS3.7]	
(2)	[F10-OS3.7]	
(3)	[F10,F81-OS3.7]	
(4)	[F10,F81-OS3.7]	
(5)	[F10-OS3.7]	
(6)	[F10-OS3.7]	
(7)	[F10-OS3.7]	
3.4.5	.2. Signs for Stairs and Ramps at Exit Level	
(1)	[F10-OS3.7]	

	Functional Statements and Objectives ⁽¹⁾
346	.1. Slip Resistance of Ramps and Stairs
(1)	(a) [F10-OS3.7] [F30-OS3.1]
(1)	(b) [F10-OS3.7] [F30-OS3.1]
(2)	[F10,F12-OS3.7] [F30-OS3.1]
(~)	[F12-OP1.2]
	[F12-OS1.2,OS1.5]
346	.2. Minimum Number of Risers
(1)	[F30-OS3.1]
	.3. Maximum Vertical Rise of Stair Flights and Required Landings
(1)	
(1)	[F10-OS3.7] [F30-OS3.1]
(3)	[F10,F12-OS3.7] [F30-OS3.1]
(4)	[F30-OS3.1]
	4. Dimensions of Landings
(1)	[F10,F12-OS3.7] [F30-OS3.1]
(1)	[F12-OP1.2]
	[F12-OS1.2,OS1.5]
(2)	[F10,F12-OS3.7] [F30-OS3.1]
(2)	[F12-OP1.2]
	[F12-OS1.2,OS1.5]
(4)	[F10,F12-OS3.7] [F30-OS3.1]
(4)	[F10,F12-OS3.7] [F30-OS3.1]
· ·	5. Handrails
	[F30-OS3.1] [F10-OS3.7]
(1)	[F30-OS3.1] [F10-OS3.7]
(2)	
(3)	[F10-OS3.7] [F30-OS3.1] [F30-OS3.1] [F10-OS3.7]
(4)	[F30-OS3.1] [F10-OS3.7]
(5)	
(7)	[F30-OS3.1] [F10-OS3.7]
(9)	[F30-OS3.1] [F10-OS3.7]
(10)	[F30-OS3.1] [F10-OS3.7]
(11)	[F73-OA1]
(11)	[F30-OS3.1] [F10-OS3.7]
(12)	[F30-OS3.1] [F10-OS3.7]
(10)	[F73-OA1]
(13)	[F30-OS3.1] [F10-OS3.7]
(15)	[F30-OS3.1] [F10-OS3.7]

	Functional Statements and Objectives ⁽¹⁾	
3.4.6	.6. Guards	
(1)	[F30-OS3.1] [F10-OS3.7]	
(2)	[F30-OS3.1] [F10-OS3.7]	
(4)	[F30-OS3.1] [F10-OS3.7]	
(5)	[F30-OS3.1]	
(6)	[F30-OS3.1]	
(7)	[F30-OS3.1]	
	.7. Ramp Slope	
(1)	[F10-OS3.7] [F30-OS3.1]	
	.8. Treads and Risers	
(1)	[F10-OS3.7] [F30-OS3.1]	
(2)	[F10-OS3.7] [F30-OS3.1]	
(3)	[F10-OS3.7] [F30-OS3.1]	
(0)	[F73-OA1]	
(4)	[F10-OS3.7] [F30-OS3.1]	
(5)	[F30-OS3.1] [F10-OS3.7]	
(6)	[F30-OS3.1] [F10-OS3.7]	
(7)	[F30-OS3.1] [F10-OS3.7]	
	[F30-OS3.1]	
(8)	[F10-OS3.7] [F30-OS3.1]	
(9)	[F30-OS3.1]	
	.9. Curved Flights in Exits	
(1)	[F10-OS3.7] [F30-OS3.1]	
(1)	[F10-OS3.7] [F30-OS3.1]	
	[F30-OS3.1] [F10-OS3.7]	
(3)	[F30-OS3.1] [F10-OS3.7] [F30-OS3.1] [F10-OS3.7]	
(4)	.10. Horizontal Exits	
(1)	[F10-OS3.7] [F10-OS3.7]	
(2)	[F10,F73-OS3.7]	
(4)		
(5)	[F10-OS3.7] .11. Doors	
	-	
(1)	[F30-OS3.1] [F10-OS3.7]	
(2)	[F30-OS3.1] [F10-OS3.7]	
(3)	[F30-OS3.1] [F10-OS3.7] Applies to portion of Code text: "No <i>exit</i> door shall open directly onto a step"	
(1)	[F81,F10-OS3.7] Applies where there is a danger of blockage from ice or snow.	
(4)	[F10-OS3.7]	

	Functional Statements and Objectives ⁽¹⁾
(5)	[F10,F12-OS3.7]
(6)	[F10-OS3.7]
3.4.6	.12. Direction of Door Swing
(1)	[F10-OS3.7]
3.4.6	.13. Self-closing Devices
(1)	[F05-OS1.5] [F06-OS1.5,OS1.2]
	[F06,F03-OP1.2]
3.4.6	.14. Sliding Doors
(2)	[F12-OS3.7]
3.4.6	.15. Revolving Doors
(1)	(a) [F30-OS3.1] [F10-OS3.7]
	(b) [F10,F12-OS3.7]
	(c) [F10-OS3.7]
	(d) [F30-OS3.1] [F10-OS3.7]
	(e) [F20-OS3.1]
(2)	[F10-OS3.7]
(3)	(a),(b),(d),(e) [F10,F81-OS3.7] [F20,F30-OS3.1]
3.4.6	.16. Door Release Hardware
(1)	[F10-OS3.7]
(2)	[F10-OS3.7]
(3)	[F10-OS3.7]
(4)	[F10,F81-OS3.7]
(5)	[F10,F81-OS3.7]
(6)	[F10-OS3.7]
	[F73-OA1]
3.4.6	.17. Security for Banks and Mercantile Floor Areas
(1)	[F02-OS1.2] Applies to sprinklered buildings.
	[F10,F81-OS3.7] Applies to exit and egress doors that comply with the stated Sentences.
(2)	[F10-OS3.7]
(3)	[F81-OS3.7]
(5)	[F10-OS1.5]
(6)	[F10-OS3.7]
(9)	[F10,F81-OS3.7]

	Functional Statements and Objectives ⁽¹⁾
3.4.6	6.18. Emergency Crossover Access to Floor Areas
(1)	[F10-OS3.7]
(3)	[F10-OS3.7]
(4)	[F10,F12-OS3.7]
(7)	[F12-OP1.2]
	[F12-OS1.2,OS1.5]
(5)	[F10-OS3.7]
	6.19. Floor Numbering
(1)	[F10,F12,F73-OS3.7]
	[F73-OA1]
	[F12-OP1.2]
	[F12-OS1.2]
	7.1. Scope
(1)	[F10,F12-OS3.7]
(2)	[F10-OS3.7] [F30-OS3.1]
	[F10-OS1.5] [F12-OS1.2]
3.4.7	7.2. Fire Escape Construction
(1)	[F05-OS1.5] [F06-OS1.2] Applies to the combustibility of materials used in the construction of fire escapes.
	[F10,F12-OS3.7] [F20-OS3.1] Applies to the type and construction of fire escapes.
	[F20-OS2.1] Applies to the type and construction of fire escapes.
3.4.7	.3. Access to Fire Escapes
(1)	[F10-OS3.7] Applies to portion of Code text: "Access to fire escapes shall be from corridors through doors at floor level"
(2)	[F30-OS3.1] [F10-OS3.7]
3.4.7	.4. Protection of Fire Escapes
(1)	[F05,F06-OS1.5]
3.4.7	7.5. Stairs
(1)	[F10-OS3.7]
(2)	[F10-OS3.7]
(3)	[F10-OS3.7] Applies to the reduction in width permitted under certain conditions.
(4)	[F10-OS3.7] [F30-OS3.1]
	7.6. Guards and Railings
(1)	[F10-OS3.7] [F30-OS3.1]
(2)	[F10-OS3.7] [F30-OS3.1]
(3)	[F10-OS3.7] [F30-OS3.1]
(4)	[F30-OS3.1]
(5)	[F30-OS3.1]
(0)	

Functional Statements and Objectives ⁽¹⁾
1. Elevators, Escalators and Dumbwaiters
[F30,F81-OS3.1] [F32,F81-OS3.3] [F36,F81-OS3.6]
[F82-OS3.1,OS3.3,OS3.6]
[F73-OA1]
1. Fire Separations for Elevator Hoistways
[F03-OS1.2]
[F03-OP1.2]
2. Vertical Service Spaces for Dumbwaiters
[F03-OS1.2]
[F03-OP1.2]
3. Fire Separations for Elevator Machine Rooms
[F03-OS1.2]
[F03-OP1.2]
[F03-OS1.2]
[F03-OP1.2]
1. Elevator Car Dimensions
[F12-OS3.7]
[F12-OS3.7]
2. Floor Numbering
[F73-OA1]
2. Electrical Wiring and Equipment
[F01-OS1.1] [F02,F03-OS1.2] [F81-OS1.4]
[F01-OP1.1] [F02,F03-OP1.2] [F81-OP1.4]
[F32-OS3.3]
3. Lightning Protection Systems
[F01,F81-OS1.1]
[F01,F81-OP1.1]
4. Storage Use Prohibition
[F01-OS1.1] [F02-OS1.2]
5. Appliances Installed outside a Building
[F03-OS1.2]
(b) [F03-OP1.2]
(a) [F03-OP3.1]

	Functional Statements and Objectives ⁽¹⁾
3.6.2	.1. Fire Separations around Service Rooms
(1)	[F03-OS1.2,OS1.4]
()	[F03-OP1.2,OP1.4]
(3)	[F01-OS1.1] [F03-OS1.2]
()	[F01-OP1.1] [F03-OP1.2]
(4)	[F03-OS1.2,OS1.4]
()	[F03-OP1.2,OP1.4]
(5)	[F03-OS1.2,OS1.4]
()	[F03-OP1.2,OP1.4]
(6)	[F03-OS1.2,OS1.4]
(-)	[F03-OP1.2,OP1.4]
(7)	[F03-OS1.2,OS1.4]
()	[F03-OP1.2,OP1.4]
3.6.2	.2. Service Rooms under Exits
(1)	[F06,F05-OS3.7]
()	[F02-OS1.2]
3.6.2	.4. Incinerator Rooms
(1)	[F02-OS1.2]
	.5. Combustible Refuse Storage
(1)	[F03-OS1.2]
()	[F03-OP1.2]
3.6.2	.6. Door Swing for Service Rooms
(1)	[F10-OS1.5] Applies to portion of Code text: "A swing-type door from a <i>service room</i> containing a <i>boiler</i> or incinerator shall swing outward from the room"
	[F30-OS3.1] Applies to portion of Code text: "A swing-type door from a service room containing a boiler or incinerator shall swing inward if the door opens onto a corridor or any room used for an assembly occupancy."
3.6.2	.7. Electrical Equipment Vaults
(2)	[F03-OS1.2,OS1.4]
	[F03-OP1.2,OP1.4]
(3)	[F02-OS1.2] [F11-OS1.5] [F03-OS1.4]
	[F02-OP1.2] [F03-OP1.4]
(4)	[F03-OS1.2,OS1.4]
	[F03-OP1.2,OP1.4]
(6)	[F81-OS1.1]
(7)	[F03-OS1.2]
(8)	[F44-OS1.1] [F03-OS1.2]

	Functional Statements and Objectives ⁽¹⁾	
(9)	[F34-OS1.1]	
(0)	[F34-OS3.3]	
	[F34-OP1.1]	
362	2.8. Emergency Power Installations	
(1)	[F03-OS1.2,OS1.4] [F06-OS1.2,OS1.5]	
(1)	[F03-OP1.2,OP1.4] [F06-OP1.2]	
2.02		
	8.1. Fire Separations for Vertical Service Spaces	
(1)	[F03-OS1.2]	
(0)	[F03-OP1.2]	
(2)	[F03-OS1.2]	
	[F03-OP1.2]	
(3)	[F03-OS1.2]	
	[F03-OP1.2]	
(4)	[F03-OS1.2]	
	[F03-OP1.2]	
(5)	[F03-OS1.2]	
	[F03-OP1.2]	
3.6.3	2. Foamed Plastic Protection	
(1)	[F02-OS1.2]	
3.6.3	3.3. Linen and Refuse Chutes	
(1)	(d),(e) [F02-OS1.2]	
	(a),(b),(c) [F41-OH2.4,OH2.5]	
(2)	[F03-OS1.2]	
	[F03-OP1.2]	
(3)	[F03-OS1.2]	
(4)	(b) [F03-OS1.2]	
	(a) [F41-OH2.4,OH2.5]	
(5)	(a) [F81,F03-OS1.2]	
	(a) [F81,F41-OH2.4,OH2.5]	
	(a) [F81,F03-OP1.2]	
	(b) [F03-OS1.2]	
	(b) [F03-OP1.2]	
	(c) [F01,F02-OS1.2]	
	(c) [F01,F02-OP1.2]	
	(d) [F05-OS1.5] [F06-OS1.5,OS1.2]	
	(d) [F06-OP1.2]	

[F02-OS1.2] [F02-OP1.2]
[FU2-OF 1.2]
[F03-OS1.2]
[F03-OP1.2]
[F02-OS1.2]
[F41-OH2.4,OH2.5]
[F03-OS1.2]
[F03-OP1.2]
[F81,F03-OS1.2] Applies to portion of Code text: "The room or bin into which a refuse chute discharges shall be of sufficient size to contain the refuse between normal intervals of emptying"
[F81,F41-OH2.4,OH2.5] Applies to portion of Code text: "The room or bin into which a refuse chute discharges shall be of sufficient size to contain the refuse between normal intervals of emptying"
[F41-OH2.4,OH2.5] Applies to portion of Code text: "The room or bin into which a refuse chute discharges shall be impervious to moisture and be equipped with a water connection and floor drain for washing-down purposes."
[F01,F02-OS1.2]
I. Exhaust Duct Negative Pressure
[F03-OS1.2]
5. Grease Duct Enclosures
[F02,F03-OS1.2]
[F02,F03-OP1.2]
[F02,F03-OS1.2]
[F02,F03-OP1.2]
2. Fire Separations for Horizontal Service Spaces
[F03-OS1.2]
[F03-OP1.2]
3. Plenum Requirements
[F02-OS1.2]
[F03-OS1.2,OS1.3]
[F03-OP1.2,OP1.3]
4. Attic or Roof Space Access
[F01,F02,F12-OS1.2]
[F01,F02,F12-OP1.2]
5. Horizontal Service Space Access
[F01,F02,F12-OS1.2]
[F01,F02,F12-OP1.2]
5. Crawl Space Access
[F01,F02,F12-OS1.2]
[F01,F02,F12-OP1.2]

	Functional Statements and Objectives ⁽¹⁾	
365	.1. Duct Materials	
(1)	[F01,F02-OS1.2]	
(1)	[F02-OS1.2]	
(4)	[F02-OS1.2]	
(4)	[F02-OS1.2]	
	2. Vibration Isolation Connectors	
(1)	[F01,F02-OS1.2]	
(2)	[F02-OS1.2] .3. Tape	
(1)	[F02-OS1.2]	
	.4. Coverings, Linings, Adhesives and Insulation	
(1)	[F02-OS1.2]	
(2)	[F02-OS1.2]	
(3)	[F02-OS1.2]	
(4)	[F02-OS1.2]	
(5)	[F02-OS1.2]	
(6)	[F02-OS1.2]	
(7)	[F01,F02-OS1.2]	
3.6.5	.5. Insulation and Coverings	
(1)	[F01,F02-OS1.2]	
(2)	[F02-OS1.2]	
(3)	[F02-OS1.2]	
(4)	[F02-OS1.2]	
3.6.5	.6. Clearance of Ducts and Plenums	
(2)	[F01-OS1.2]	
(3)	[F01-OS1.2]	
(4)	[F01-OS1.2]	
(5)	[F01-OS1.2]	
3.6.5	.7. Supply, Return, Intake and Exhaust-Air Openings	
(1)	[F02-OS1.2]	
3.6.5	.8. Return-Air System	
(1)	[F02-OS1.2]	
(2)	[F01,F02-OS1.2]	
(3)	[F01,F02-OS1.2]	
(4)	[F01,F02-OS1.2]	
3.7.1	3.7.1.1. Room and Space Height	
(1)	[F30-OS3.1]	
	I	

	Functional Statements and Objectives ⁽¹⁾	
3.7.2	.1. Plumbing and Drainage Systems	
(1)	[F72-OH2.1]	
(2)	[F72-OH2.1]	
3.7.2	2. Water Closets	
(1)	[F72-OH2.1] Applies to portion of Code text: " water closets shall be provided"	
(6)	[F72-OH2.1]	
(7)	[F72-OH2.1]	
(8)	[F72-OH2.1]	
(9)	[F72-OH2.1]	
(10)	[F72-OH2.1]	
(11)	[F72-OH2.1]	
(12)	[F72-OH2.1]	
(13)	[F72-OH2.1]	
(14)	[F72-OH2.1]	
(15)	[F72-OH2.1]	
(16)	[F72-OH2.1]	
3.7.2	3. Lavatories	
(1)	[F71-OH2.3]	
(3)	[F30-OS3.1]	
(4)	[F71-OH2.3]	
3.7.2	4. Mobile Home Facilities	
(1)	[F72-OH2.1] [F71-OH2.3]	
(2)	[F72-OH2.1]	
(3)	[F71-OH2.3] Applies to the minimum number of laundry trays or similar facilities, and of bathtubs or showers for each sex.	
3.7.2	5. Safety Glass	
(1)	[F20-OS3.1]	
3.7.2	6. Surface Protection	
(1)	[F72-OH2.1] [F40-OH2.4]	
(2)	[F72-OH2.1] [F40-OH2.4]	
3.7.2	7. Floor Drain	
(1)	[F40-OH2.4]	
	[F30-OS3.1]	
3.7.2	8. Grab Bars	
(1)	[F20-OS3.1]	

	Functional Statements and Objectives ⁽¹⁾	
3.7 2	.9. Bathtubs	
(1)	[F74-OA2]	
(.)	(b) [F31-OS3.2]	
	(d) [F30-OS3.1]	
373	3.1. Medical Gas Piping	
(1)	[F43,F81,F82-OS3.4]	
(1)		
	[F01,F02-OS1.1]	
2.0.2	[F01,F02-OP1.1]	
	2.2. Entrances	
(1)	[F73-OA1]	
(2)	[F73-OA1]	
(5)	[F73-OA1]	
(6)	[F74-OA2]	
(1)	[F73-OA1]	
(3)	[F74-OA2]	
3.8.2	2.4. <u>Path of Travel</u> to Storeys Served by Escalators and Moving Walks	
(1)	[F73-OA1]	
(2)	[F73-OA1]	
3.8.2	2.5. <u>Path of Travel</u> to Parking Areas and Passenger-Loading Zones	
(1)	[F73-OA1]	
(2)	[F73-OA1]	
<u>(3)</u>	[F73-OA1]	
<u>3.8.2</u>	.6. Controls and Outlets	
(1)	[F74-OA2]	
<u>(2)</u>	[F74-OA2]	
3.8.2	2.7. Power Door Operators	
(1)	[F73-OA1]	
3.8.2	.8. Plumbing Facilities	
(1)	[F74-OA2]	
	[F72-OH2.1] [F71-OH2.3]	
(3)	[F72-OH2.1]	
	[F73-OA1]	
	[F74-OA2]	
<u>(5)</u>	[F74-OA2]	
<u>(6)</u>	[F74-OA2]	
(7)	[F74-OA2]	
· 7		

	Functional Statements and Objectives ⁽¹⁾	
<u>(8)</u>		
<u>(9)</u>	[F74-OA2]	
<u>(10)</u>	[F74-OA2]	
(11)	[F74-OA2]	
	9. Assistive Listening Devices	
<u>(1)</u>	[F74-OA2]	
<u>(2)</u>	[F74-OA2]	
3.8.2.	10. Signs and Indicators	
(1)	[F74-OA2]	
(2)	[F74-OA2]	
<u>(3)</u>	[F30-OS3.1]	
	[F73-OA1]	
3.8.2.	11. Counters and Counters for Telephones	
(1)	[F74-OA2]	
(2)	[F74-OA2]	
<u>3.8.2</u> .	12. Sleeping Rooms and Bed Spaces	
<u>(2)</u>	[F73-OA1] [F74-OA2]	
<u>(3)</u>	[F11-OS1.5]	
<u>(4)</u>	[F11-OS1.5]	
3.8.3.	2. Accessible Path of Travel	
(1)	[F73-OA1]	
(2)	[F30-OS3.1]	
	[F73-OA1]	
	Reserved	
	Reserved	
	Reserved	
(4)	[F73-OA1]	
<u>(5)</u>	[F30-OS3.1]	
	[F73-OA1] [F74-OA2]	
	3. Exterior Walks	
(1)	(a) [F73-OA1]	
	(a) [F30-OS3.1]	
	(b) [F73-OA1]	
<u>(2)</u>	[F30-OS3.1]	
	[F73-OA1]	

	Functional Statements and Objectives ⁽¹⁾
3.8.3.	4. Passenger-Loading Zones
(1)	(a) [F74-OA2]
	(b) [F73-OA1]
	(c) [F74-OA2]
3.8.3	5. Ramps
(1)	(a).(b),(c),(d),(e) [F73-OA1]
(')	(b),(c),(d),(e),(f) [F30-OS3.1]
	Reserved
	Reserved
	Reserved
(4)	Reserved
(4)	(a) [F73-OA1]
(5)	(b) and (c) [F30-OS3.1]
(5)	[F30-OS3.1]
	6. Doorways and Doors
(2)	[F73-OA1]
(3)	[F74-OA2]
(4)	[F74-OA2]
	[F10-OS3.7]
(5)	[F73-OA1] [F74-OA2]
	[F10 <u>,F30</u> - <u>OS3.1,</u> OS3.7]
(6)	[F73-OA1]
(7)	[F30,F73-OS3.1]
(8)	[F73-OA1]
(10)	[F30-OS3.1]
	[F73-OA1]
(11)	[F73-OA1]
(12)	[F30-OS3.1]
	[F73-OA1]
(14)	[F73-OA1]
3.8.3.	7. Passenger-Elevating Devices
(1)	[F30-OS3.1] [F10-OS3.7]
3.8.3.	8. Controls <u>and Outlets</u>
(1)	[F74-OA2]
	[F10-OS3.7]
<u>(2)</u>	[F74-OA2]

	Functional Statements and Objectives ⁽¹⁾	
3.8.3	.9. Signs <u>and Indicators</u>	
(1)	[F74-OA2]	
	[F73-OA1]	
(2)	[F10-OS3.7]	
	[F73-OA1] [F74-OA2]	
(3)	[F30-OS3.1]	
	[F73-OA1]	
3.8.3	2.10. Drinking Fountains	
(1)	[F74-OA2]	
3.8.3	2.11. Water-Closet Stalls	
(1)	[F74-OA2]	
	[F72-OH2.1]	
	(c)(i) [F74-OA2]	
	(e) and (f) [F30,F20-OS3.1]	
	(g) [F30-OS3.1] Applies to portion of Code text: " be equipped with a coat hook projecting not more than 50 mm from the wall"	
3.8.3	.12. Universal Washrooms	
(1)	[F74-OA2]	
	(b) [F10-OS3.7]	
	(f) [F30-OS3.1] Applies to the requirement for a coat hook.	
	(h) [F74-OA2] Applies to the requirement for a shelf.	
	[F72-OH2.1] [F71-OH2.3]	
	(b) [F74-OA2] Applies to portion of Code text: " b) a door capable of being locked from the inside"	
3.8.3	.13. Water Closets	
(1)	[F74-OA2]	
	[F72-OH2.1]	
3.8.3	.14. Urinals	
(1)	[F74-OA2]	
	(f) [F30-OS3.1]	
3.8.3	.15. Lavatories and Mirrors	
(1)	[F74-OA2]	
	[F71-OH2.3]	
	(e) [F31-OS3.2]	
(2)	[F74-OA2]	

	Functional Statements and Objectives ⁽¹⁾	
3.8.3	.16. Showers	
(<u>1</u>)	[F74-OA2]	
<u></u>	(d),(e).(f).(g).(h).(i).(j) [F30-OS3.1]	
	(a) [F20-OS3.1]	
	(g) [F80-OH2.3]	
	(g) [F71- <u>OH2.3]</u> Applies to portion of Code text: " v) designed to be easily cleaned"	
	(b) (i) [F31-OS3.2]	
383	(ii). (ii) (ii) (ii) (iii) (ii	
-	1	
<u>(1)</u>	[F74-OA2]	
	(e).(h) [F31-OS3.2]	
2.0.0	(<u>f).(g).(h).(i).(j)</u> [F30-OS3.1]	
	.18. Assistive Listening Devices	
(1)	[F74-OA2]	
	[F11-OS3.7]	
-	.19. Counters	
(1)	[F74-OA2]	
	.20. Shelves or Counters for Telephones	
(1)	[F74-OA2]	
(2)	[F74-OA2]	
3.8.3	.21. Spaces in Seating Area	
(1)	[F74-OA2] Applies to entire Sentence except for portion of Code text: " without infringing on egress from any row of seating or any aisle requirements"	
	[F30-OS3.1] Applies to portion of Code text: " level, or level with removable seats"	
	(d) [F10-OS3.7]	
3.8.3	.22. Sleeping Rooms and Bed Spaces	
(1)	[F73-OA1] [F74-OA2]	
3.8.4	.2. Specific Requirements	
(1)	[F73-OA1]	
3.8.4	.3. Vertical Additions	
(1)	[F73-OA1] [F74-OA2]	
3.8.4	.4. Horizontal Additions	
(1)	[F73-OA1] [F74-OA2]	
3.8.4	.5. Alterations and Occupancy Change	
(1)	[F73-OA1] [F74-OA2]	
3.8.4	.6. Sleeping Rooms and Bed Spaces	
(1)	[F74-OA2]	

	Functional Statements and Objectives ⁽¹⁾	
3.8.4	3.8.4.7. Existing Facilities	
(1)	[F74-OA2]	
3.8.4	8. Egress from Floor Areas	
(1)	[F73-OA1]	
	[F10, F73-OS1.5]	
<u>3.8.5</u>	3. Building Access Requirements	
(1)	[E75-OA1] [E75-OA2]	
<u>(2)</u>	[F75-OA1] [F75-OA2]	
<u>(3)</u>	[F75-OA1] [F75-OA2]	
<u>3.8.5</u>	4. Adaptable Dwelling Unit Doorways	
<u>(1)</u>	[F75-OA1] [F75-OA2]	
<u>(2)</u>	[F75-OA1] [F75-OA2]	
<u>3.8.5</u>	5. Adaptable Dwelling Unit Bathrooms	
<u>(1)</u>	[F75-OA1] [F75-OA2]	
<u>(2)</u>	[<u>F75-OA2]</u>	
<u>3.8.5</u>	6. Adaptable Dwelling Unit Kitchens	
<u>(1)</u>	[F75-OA2]	
<u>3.8.5</u>	7. Controls, Switches and Outlets	
<u>(1)</u>	[<u>F75-OA2]</u>	
Mater		

Notes to Table 3.10.1.1.:

(1) See Parts 2 and 3 of Division A.