

Section 6.1. General

6.1.1. General

6.1.1.1. Application

1) This Part includes requirements for the inspection, testing, maintenance, and operation of portable extinguishers, water-based fire protection systems, special extinguishing systems, fire alarm systems, emergency electrical power supply systems, emergency lighting, and *exit* signs.

6.1.1.2. Maintenance

1) Fire protection installations shall be maintained in operating condition. (See Note A-6.1.1.2.(1).)

6.1.1.3. Notification

1) Where tests, repairs or alterations are made to fire protection installations, including sprinkler and standpipe systems, a procedure of notification shall be established. (See Note A-6.1.1.3.(1).)

6.1.1.4. Protection during Shutdown

1) When any portion of a fire protection system is temporarily shut down, alternative measures shall be taken to ensure that protection is maintained. (See Note A-6.1.1.4.(1).)