

Section 6.2. Portable Extinguishers

6.2.1. General

6.2.1.1. Inspection, Testing and Maintenance

- 1) Portable extinguishers shall be inspected, tested and maintained in conformance with NFPA 10, “Portable Fire Extinguishers.”