

## **Section 6.7. Smoke Alarms and Carbon Monoxide Alarms**

### **6.7.1. General**

#### **6.7.1.1. Inspection, Testing and Maintenance**

- 1)** *Smoke alarms* shall be inspected, tested and maintained in conformance with CAN/ULC-S552, “Inspection, Testing and Maintenance of Smoke Alarms.”
- 2)** A record shall be kept of all testing of *smoke alarms* installed in hotels and motels and shall be retained in conformance with Article 2.2.1.2. of Division C.
- 3)** Carbon monoxide alarms shall be inspected, tested and maintained in conformance with the manufacturer’s instructions.