

## **Section 6.5. Thermal Insulation Systems**

### **6.5.1. Insulation**

#### **6.5.1.1. Insulation and Coverings**

(See Note A-6.3.2.5.)

- 1)** Insulation and coverings on pipes shall comply with Article 3.6.5.5.
- 2)** Insulation and coverings on pipes shall be composed of material that will withstand deterioration from softening, melting, mildew and mould at the operating temperature of the system.
- 3)** Exposed piping or equipment subject to human contact shall be insulated so that the temperature of the exposed surface does not exceed 70°C. (See Note A-6.5.1.1.(3).)