

## **Section D-5 Protection of Openings in Fire-Rated Assemblies**

### **D-5.1. Scope**

#### **D-5.1.1. Installation Information**

- 1) The information in this Section specifies requirements for the installation of fire doors and fire dampers in gypsum-board-protected stud wall assemblies.

### **D-5.2. Installation of Fire Doors and Fire Dampers**

#### **D-5.2.1. References**

- 1) Fire doors and fire dampers in gypsum-board-protected steel stud non-loadbearing walls required to have a fire-resistance rating shall be installed in conformance with Section 9.24. of this By-law and the applicable requirements of NFPA 80, “Fire Doors and Other Opening Protectives.”
- 2) Fire doors and fire dampers in gypsum-board-protected wood stud walls required to have a fire-resistance rating shall be installed in conformance with Section 9.23. of this By-law and the applicable requirements of NFPA 80, “Fire Doors and Other Opening Protectives.”